



- 1) PIPE MATERIAL - SPRINKLER PIPE - MS (CLASS C) HEAVY DUTY
- 2) JOINING OF PIPE - DRAIN PIPE - G.I. (CLASS B) MEDIUM DUTY
- 3) UP TO 40 MM DIA - SCREW JOINT
- 4) 50 MM & ABOVE DIA - WELDED JOINT
- 5) MATERIAL OF SLEEVE - M.S. PIPE TACK WELDED WITH REINFORCEMENT
- 6) DISTANCE OF DEFLECTORS FROM CEILING
- 7) SPRINKLER TYPE OF SPRINKLER
- 8) NON COMBUSTIBLE
- 9) PLAN OR SLOPING
- 10) MAX. PREFERRED AND SPRAY TYPE
- 11) 75 MM 150 MM 150 MM
- 12) NON COMBUSTIBLE
- 13) PLAN OR SLOPING
- 14) 100 MM 150 MM 150 MM

Architect:
Client: ARMY WELFARE HOUSING ORGANIZATION
 SOUTH HUTMENTS, KASHMIR HOUSE
 RAJAJI MARK, NEW DELHI-110011

Project Code: GH/2045

Project Title: AWHO-VRINDAVAN YOJNA
 AT PLOT NO. GH-05 & CH-06
 SEC-8B, VANDANA AMAS YOJNA, LICKNOW, (UP)

Drawing Title: STILL LVL PLAN (DXA)
 TOWER-A, B & C (SITE - 02)

Scale: 1:50

Date: 19/07/16

Checked: HIRANSHU

Drawn: ANHOF/AB/C/301

Revision: 195

Notes:
 1. ALL PIPING SHALL BE CARVED OF WITH STANDING 15% OF THE MAXIMUM WORKING PRESSURE FOR MINIMUM TWO HOURS.
 2. EXTRA SUPPORTS SHALL BE PROVIDED AT THE BENDS AND AT HEAVY FITTINGS. LINE VALVES TO AVOID INDUCE STRESS ON THE PIPES.
 3. THE THICKNESS OF CLAMP SHOULD BE MINIMUM 3MM.