



**INDEX**

- 1- 200 φ PVC Pipe
- 2- 160 φ PVC Pipe
- 3- 110 φ PVC Pipe
- 4- 110 φ PVC Pipe
- 5- Sewer Valve
- 6- Air Valve



S. No.	SYMBOL	DESCRIPTION
1		200 φ PVC PIPE WITH CHAMBER
2		160 φ PVC PIPE WITH CHAMBER
3		110 φ PVC PIPE WITH CHAMBER
4		110 φ PVC PIPE WITH CHAMBER
5		SEWER VALVE
6		AIR VALVE

**NOTES:**

1. DEPTH OF PIPE SHALL BE 1.0M BELOW GROUND LEVEL.
2. LEFT TO USE FOR DATA REFER AND 200 AND ABOVE DI PIPE SHALL BE USED.
3. THE DIAMETER OF PIPE AS INDICATED IN THE DRAWING DEFERS THE NOMINAL PIPE SIZE.
4. BUTTERFLY TYPE OF SLIDE VALVE SHALL FOLLOW NON RETURN VALVE.
5. THURST RINGS SHALL HAVE TO BE PROVIDED IN CASE OF SLAB SEND.

**U.P. AVASEVAM VIKAS PARISHAD**  
 REGIONAL VANDANAYAKA  
 PROPOSED LIG & EWS (G+3) TYPES FLATS  
 AT SECTOR-7A, AWADH VIHAR YOJNA LUDHNOV.

**EXTERNAL WATER SUPPLY SYSTEM**  
 CONSULTING CHAMBER  
 JAN-2017 1:1000

P.171 AMRITHI KHANV  
 CONSULTING CHAMBER  
 LUDHNOV  
 PH NO. 94511-9523 99191-9523 (O)  
 MAIL ID : p171amrithi@rediffmail.com