

By Regd Post

Wg Cdr 

Tele: 011-23060231/5216

Air Headquarters
Vayu Bhavan
Rafi Marg
New Delhi -110 106

Air HQ/S 17726/4/ATS (Ty BM - MCCXXXV)


17 Apr 12

M/s Gardenia India Ltd
Plot No. 9, Sector-75
Noida(UP) -

**ISSUE OF NOC FOR CONSTRUCTION OF BUILDING FOR GROUP HOUSING
PROJECT AT SECTOR-18, VASUNDRA, GHAZIABAD**

1. Reference is made to your application No. GIL/NOC-IAF/GZB/11 dated 27 Dec 12.
2. Annexed please find an ink signed copy of 'No Objection Certificate' on the subject issued vide GoI letter MoD No. Air HQ/S 17726/4/ATS (PC-CMXL)/Dy.No.295/F/D (Air-II) dated 13 Apr 12. You may please acknowledge the receipt of this letter.

Yours faithfully,


(A Mudgal)
Wg Cdr
JD Ops (ATS)

Annexure: As stated (ink signed copy)

No. Air HQ/S 17726/4/ATS(PC-CMXL)
Dy. No. 295/F/D(Air-II)
Government of India
Ministry of Defence

New Delhi, the 13th Apr, 2012.

To

M/s Gardenia India Ltd.
Plot No. 9, Sector – 75,
Noida (UP).

Subject : **Issue of 'NOC' for construction of building for group housing project at Sector – 18, Vasundra, Ghaziabad by M/s Gardenia India Ltd.**

Sir,

I am directed to refer to your application No. GIL/NOC-IAF/GZB/11 dated 27.12.2011 on the above subject and to say that Air HQ has no objection for construction of 65.25 meters high building for group housing project at Plot No. 18/GH-12, Sec – 18, Vasundra, Ghaziabad, UP by M/s Gardenia India Ltd, subject to the following conditions:-

- a) The vertical extent (highest point) of the building shall not exceed 65.25 meters above ground level/ 268.25 meters above mean sea level.
- b) Standard obstruction lightings to be provided by the company. The lights shall be switched 'ON' during night and poor visibility. Provision shall be made for standby power supply to the light to keep them 'ON' during power failure.
- c) Periodic maintenance of obstruction lights is to be carried out by the company at regular intervals to keep them in visible/serviceable condition.
- d) A garbage treatment plant shall be installed prior to the construction of buildings for the purpose of avoiding bird activity. The plant shall be shown to the AOC/his nominated representative at AF Stn Hindan on installation.
- e) The commencement, completion of works inclusive installation of obstruction lights shall be intimated to AOC, AF Stn Hindan.
- f) The validity of this NOC is five years from the date of issue. If the construction for which NOC has been issued, does not complete within five years of issue or found to be in deviation from original proposal the NOC shall be deemed null and void. It will be the responsibility of the applicant to obtain fresh NOC for the proposal.
- g) Required security clearance should be obtained from MHA/IB of the foreign Nationals and Indian representative employed/to be employed by the company in India.

2. You are also requested to obtain No Objection from other concerned Government Organization/Agencies as required.

Yours faithfully,



(A.S. Chowdhury)

Under Secretary to the Government of India