



- NOTES:**
- 1) Clear height of 11 KV METER room shall be minimum 3.6 mtr. below clear beam.
 - 2) Plinth Level of Meter room shall be 600 mm above final finished ground level.
 - 3) Trench detail shall be finalized after receiving foundation detail of METERING Panel

R2	18.11.2013	CSS DIMENSIONS REVISED.
R1	25.06.2013	CSS USED IN PLACE OF OPEN TYPE TRANSFORMER.
R0	04.12.2012	GFC ISSUED.

Rev. No.	Date	Revision
----------	------	----------

Project :
AJNARA DAFFODIL
PLOT NO.-7B, SECTOR- 137, NOIDA.

Title :
SITE PLAN

Subtitle :
ELECTRICAL SETTING OUT PLAN
AT SITE PLAN

Drawing Released For :
 APPROVAL SUBMISSION
 ADVANCE COPY CONSTRUCTION

Drg. No. : DD / ELEC / EXT / 01

Scale : 1:475 Drawn By : Najmul

Date : Oct. 2012 Design By : Ateeq Ur Rehman

Ckd By : Anand Havelia

Architects :
DEEPAK MEHTA & ASSOCIATES
ARCHITECTS, PLANNERS, VALUERS, LANDSCAPE & INTERIORS
2nd FLOOR, PLOT NO. 16, ABHISHEK PLAZA, L.S.C. MAYUR VIHAR
PH II, DELHI - 91, INDIA TELEPHONE : 91 - 11 - 65272180, 91 - 11 - 22770180,
TELEFAX : 91 - 11 - 22770180

services consultant
Consummate Engineering Services (P) Ltd.
Noida Office : B - 67, Sector - 67, Noida - 201 301
Tel : (0120) 2993900 / 30 Lines
Lko Office : R 006, Rohtas Plumeria, Gomti Nagar, Lucknow
Tel : (0522) 6515455
e mail : mail@cespl.in, website : www.cespl.in