



# AGSS ANALYTICAL AND RESEARCH LAB (P) LTD.

A Government Approved Testing Laboratory

(An ISO-9001 : 2015 Certified Company)

C-37/2 (Back Side) Lawrence Road, Industrial Area, Delhi-110035

Ph. : 011-45022985, 9311654060

E-mail : support@agssl.com Web : www.agssl.com

## TEST REPORT

Issued to: M/s Alaknanda Sunshine Infra Developers LLP Bijnor to Sisandi Road, Near SDRF, Gram Ratauli, Lucknow	LAB REFERENCE NO WNA2020070411068
Sample Issue Date	04/07/2020
Report Issue Date	08/07/2020

Sample Particulars: STP Outlet Water

Sample Registration Date	04/07/2020
Analysis Starting Date	04/07/2020
Analysis Completion Date	08/07/2020
Name Of The Product	STP Outlet Water
Quantity Received	1Ltr in Plastic Bottle
Tests Required	Chemical Test
Sampling Done By	AGSS Representative

SAMPLE TESTED AS RECEIVED

Sr. No.	Test Parameter	Unit of Measurement	Results	Limit as Per CPCB	Method of Testing
1	pH	-	7.42	6.5-9.0	IS:3025(P-11)
2	Total Suspended Solid	mg/L	42	100 Max	IS:3025(P-18)
3	Oil & Grease	mg/L	1.9	10 Max	IS:3025(P-39)
4	Chemical Oxygen Demand	mg/L	82	250 Max	IS:3025(P-58)
5	Bio Chemical Oxygen Demand (at 27°C for 3 days) (Max)	mg/L	10	30 Max	IS:3025(P-44)
6	Total Dissolved Solid	mg/L	815	2100 Max	IS:3025(P-16)
7	Total Nitrogen	mg/L	0.97	5 Max	IS:3025(P-34)

Checked By  
Chandra Dev

Dr. Shival Singh

Director Technical  
(Authorized Signatory)



\*\*\*\*\*End of Test Report\*\*\*\*\*

NOTE : (1) The laboratory accepts the responsibility for content of report. (2) The above result pertain only to the sample tested and applicable parameters. (3) Test report shall not be reproduced except in full, without written approval of the laboratory. (4) This test report shall not be reproduced wholly or in part and can not be used as an evidence in the court of law without written approval of M/S AGSS. (5) The sample will be stored up to 20 days from the date of issue of test certificate unless otherwise specified. (6) Sample not drawn by M/S AGSS Lab, unless specified in report. (7) All disputes are subject to the Delhi jurisdiction.

