

[illegible]

RWH Detail For Parking
Total Number of RWH = 02

- 1) All Wall / Slab / Base of RWH Shall Be Strictly As Per Structure Consultants Design & Detail.
- 2) The Bore Well Pipe of Recharge Pit Should Be Left At Least 5 m Above The Known Highest Water Table To Avoid Any Possible Pollution To The Aquifer.
- 3) The Slots Shall Start Below The Level of Foundation.

..	..	..
Rev. No.	Date	Revision

Project :
**PROPOSED COMMERCIAL COMPLEX
AT PLOT NO. 17 GYC, YEIDA
GR. NOIDA.(U.P.)**

Drawing Released For :

☐ ADVANCE COPY	☒ SUBMISSION
☐ APPROVAL	☐ CONSTRUCTION

Architects :
A PLUS DESIGN ASSOCIATES.
J-16, SECTOR-41 NOIDA - 201303,
Tel.:9625775674
email : aplusdesignassociates@gmail.com

Title :
TYPICAL DETAIL

Drg. No : RWH - 01

Scale : N.T.S

Subtitle :
RAIN WATER HARVESTING DETAIL

Drawn By : Prem Saini

Design By : Badri Vishal

Date : 17.01.2022

Ckd By : Anand Havelia

services consultant

Consummate Engineering Services (P) Ltd.



Noida Office : B - 67, Sector - 67, Noida - 201 301
Lko. Office : R 006, Rohtas Plumeria, Gomti Nagar, Lucknow
Tel : (0120) 2303500 (30 Lines)
e mail : mail@cespi.in, website : www.cespi.in