

# Central Ground Water Authority

Ministry of Water Resources  
Government of India

No. 21-4(414)/NR/CGWA/2012- 4304

Dated-

6 AUG 2012

To,  
The Director,  
M/s Experion Developers Private Ltd.  
Room No. 03 - 04, Ground Floor,  
Tower - A, Unitech Business Park, Sector 41,  
Gurgaon, Haryana

- Sub: Request for Ground Water clearance in respect of M/s Experion Developers Private Ltd., for their proposed Mixed Use Project at Plot No. TCG-1/A-V-7, Vibhuti Khand, Gomti Nagar, Lucknow, Uttar Pradesh -reg.**

Sir,

The area where the project falls comes under Safe category as per the ground water assessment carried out by Central Ground Water Board. Since the total requirement of ground water is 288 m<sup>3</sup>/day, NOC is not required for ground water withdrawal from Central Ground Water Authority. However, to neutralize the adverse impact of ground water withdrawal that may arise on a long term basis, the industry/ project is advised to undertake the following measures:


1. Ground Water withdrawal shall not exceed the proposed quantity of 288 m<sup>3</sup>/day.
2. All abstraction structures should be fitted with water meter by the industry and monitoring of ground water abstraction to be undertaken accordingly on regular basis, at least once in a month. The data may be submitted on a yearly basis to the Regional Director, Central Ground Water Board, Northern Region, Lucknow for perusal and records.
3. The industry should adopt and implement artificial recharge measures/rain water harvesting measures for augmenting the ground water resources of the area as per the hydrogeological investigation.
4. The industry shall ensure proper conservation measures, recycling and reuse of waste water after adequate treatment.
5. The industry shall monitor the ambient ground water regime of the area through piezometers and submit the data on a yearly basis to the Regional Director, Central Ground Water Board, Northern Region, Lucknow for perusal and records.

Yours faithfully,

Regional Director

**Copy for information to:**

1. The Member Secretary, Uttar Pradesh State Pollution Control Board, Picup Bhawan, 3<sup>rd</sup> Floor, B- Block, Vibhuti Khand, Gomti Nagar, Lucknow, with a request to ensure that Rain Water Harvesting and Artificial Recharge methods are being implemented by the firm and quantity of withdrawal is not exceeding 288 m<sup>3</sup>/day.
2. The Regional Director, Central Ground Water Board, Northern Region, Bhujal Bhawan, Sector B, Sitapur Road Yojana, Lucknow. This has reference to your letter No. 10(1)/CGWA/NR/GWC/2012 - 1405 dated 11.07.2012.
3. The TS to Chairman, Central Ground Water Board, Bhujal Bhawan, CGO Complex, NH-IV, Faridabad.

  
Regional Director