



NOTE :-
 SLAB / STRCTURE BELOW DG SETS TO BE DESIGN AS PER DYNAMIC LOAD OF EACH DG SETS

1. STATIC LOAD OF 500 KVA DG SETS IS 6000 KG. DYNAMIC LOAD IS 2.5 TIMES TO STATIC LOAD i.e.15000 KG.
2. STATIC LOAD OF 750 KVA DG SETS IS 10200 KG. DYNAMIC LOAD IS 2.5 TIMES TO STATIC LOAD i.e.25500 KG.
3. STATIC LOAD OF 1010 KVA DG SETS IS 18700 KG. DYNAMIC LOAD IS 2.5 TIMES TO STATIC LOAD i.e.46750 KG.

For Expressway Hospitality Pvt. Ltd.
[Signature]
 Authorised Signatory



SPACE COMBINE ASSOCIATES
 65, REGAL BUILDING,
 CONNAUGHT PLACE, NEW DELHI
 011-23366563, 23348363, 40193646
[Signature]

rev. no.	date	revision

project
PROPOSED COMMERCIAL
 AT PLOT NO - P-5a & P-5b, SECTOR - 134,
 NOIDA, UP

title
EIA SUBMISSION

subtitle
EXTERNAL ELECTRICAL LAYOUT

drawing released for
 APPROVAL SUBMISSION
 ADVANCE COPY CONSTRUCTION

drg. no. CES / SP/ PL- 05 drawn by Mandeep Singh
 scale 1 : 225 designed by M.S
 date 06.11.2025 checked by Narender

PRINCIPAL ARCHITECT:
 **SPACE COMBINE ASSOCIATES**
 ARCHITECTS | STRUCTURE ENGINEERS | INTERIOR DESIGNERS
 65 REGAL BUILDING, CONNAUGHT PLACE
 NEW DELHI - 110001 (INDIA)
 +91 11 49193646 | +91 11 23366563
 STUDIO.SCAR@GMAIL.COM | WWW.STUDIOSCA.IN

cespl Cespl Consultants Pvt. Ltd.
 B-67, Sector-67, Noida - 201301
 Tel: (0120) 3225400 / 3225401
 e mail : mail@cespl.in, website : www.cespl.in