

GENERAL NOTES

- ALL DIMENSIONS ARE IN MM. UNLESS OTHERWISE STATED.
- ONLY WRITTEN DIMENSIONS ARE TO BE FOLLOWED. DO NOT MEASURE THE DRAWING.
- ALL DRAWINGS ARE TO BE SIMULTANEOUSLY READ ALONG WITH RELEVANT SERVICES & CONSTRUCTION DRAWINGS, WHEREVER APPLICABLE.
- ALL MATERIAL FINISHES ARE TO BE EXPRESSLY APPROVED BY THE ARCHITECT &/OR THE RELEVANT CONSULTANTS.

PLUMBING & FIRE SERVICES LEGEND:

- SEWER MANHOLE WITH 600 x 600 MM RECESSED TYPE FRP MANHOLE COVER (MANHOLE DIA AS DESIGN CHART).
- STORM WATER MANHOLE WITH 600 x 600 MM RECESSED TYPE FRP MANHOLE COVER (MANHOLE DIA AS DESIGN CHART).
- 450 x 450 MM CATCH BASIN COVERED WITH PERFORATED SPRC COVER WITH FRAME.
- 600 x 600 MM CATCH BASIN COVERED WITH PERFORATED SPRC COVER WITH FRAME.
- 900 x 800 MM STORM WATER MANHOLE WITH 600 x 600 MM RECESSED TYPE MANHOLE COVER.
- 900 x 800 MM SEWER BRANCH MANHOLE WITH 600 x 600 MM RECESSED TYPE MANHOLE COVER.
- 450 x 450 MM GULLY TRAP WITH 450 x 450 MM AIR TIGHT CI MANHOLE COVER WITH FRAME.
- BUTTERFLY VALVE WITH CHAMBER 750 x 750 MM 600 x 600 MM RECESSED TYPE MANHOLE COVER WITH FRAME.
- 150N RETURN VALVE (RV) WITH CHAMBER 750 x 750 MM 600 x 600 MM RECESSED TYPE MANHOLE COVER WITH FRAME.
- 1500 PP SOL PIPE, SLOPE=1:100.
- 1500 PP WASTE PIPE, SLOPE=1:100.
- EXTERNAL SEWER LINE (DIA AS / DESIGN CHART).
- 1500 RCP 150 INTERNAL STORM WATER LINE, S=1:195.
- EXTERNAL STORM WATER LINE (DIA AS / DESIGN CHART).
- DOMESTIC WATER SUPPLY LINE.
- FLUSHING WATER SUPPLY LINE.
- GARDEN IRRIGATION WATER SUPPLY LINE.
- EXTERNAL FIRE HYDRANT LINE.
- 800 UPVC SCH-80 DRAINAGE DUMP RISER.
- MUNICIPAL WATER SUPPLY LINE.
- TUBE WELL WATER SUPPLY LINE.
- 110 OD UPVC 6 KG. PRESSURE AGR HALF ROUND SUB-SOIL DRAIN PIPE.
- 1000 WEEP HOLE AT BOTTOM LEVEL OF PLANTER.
- GARDEN HYDRANT WITH CHAMBER 300 x 300 MM.
- EXTERNAL FIRE HYDRANT CABINET (750 x 600 x 250) MM.
- RECHARGE PIT, 3000 MM DIA.
- RESULTING CHAMBER (1500 x 3000) MM.
- 110 OD PP TERRACE RAIN WATER PIPE.
- 180 OD PP TERRACE RAIN WATER PIPE.
- 90 OD PP BALCONY RAIN WATER PIPE.
- 110 OD HDPE PUDDLE FLANGE AT BASEMENT ROOF SLAB FOR SUB-SOIL DRAINAGE.
- 1500 MS HOT DIP GALVANIZED PUDDLE FLANGE AT BASEMENT ROOF SLAB FOR EXTERNAL FIRE HYDRANT (EPH).
- 1500 MS HOT DIP GALVANIZED PUDDLE FLANGE AT BASEMENT ROOF SLAB FOR EXTERNAL FIRE HYDRANT (EPH).
- 1500 MS HOT DIP GALVANIZED PUDDLE FLANGE AT BASEMENT ROOF SLAB FOR 2 WAY FIRE BRIGADE WITHDRAWAL CONNECTION.
- 4 WAY FIRE BRIGADE INLET CONNECTION FOR U.G. FIRE TANK, PIPE DIA 1500.
- 4 WAY FIRE BRIGADE INLET CONNECTION FOR FIRE HYDRANT LINE, PIPE DIA 1500.
- 4 WAY FIRE BRIGADE INLET CONNECTION FOR SPRINKLER LINE, PIPE DIA 1500.
- 2 WAY FIRE BRIGADE WITHDRAWAL CONNECTION FROM FIRE TANK, PIPE DIA 1500.





PARADISE CONSULTANTS
 PLOT NO. 06, BASEMENT, POCKET-1, JAGOLA VIHAR
 NEAR LAYERS STYLE MALL, NEW DELHI-110025, INDIA
 PHONE: 011-29943001, 41020619
 E-MAIL: paradiseconsultants@gmail.com
 Web: www.paradiseconsultants.com

CONSULTING STRUCTURAL ENGINEERS
 G-70, 2nd FLOOR, JASWANT PLAZA, NEAR KALINDI KURU
 MAIN SARITA VIHAR ROAD, CHH-LA, NEW DELHI-110025
 PHONE NO. +91-11-26247345, 87 & FAX: 26240739
 E-MAIL: rnc_consultants@hotmail.com
 Web: www.rncinternational.com

M/S OCEAN INFRAHEIGHTS PVT. LTD.
 (FORMERLY M/S U.Y. INDUSTRIES PVT. LTD.)
 PLOT NO. -11, SECTOR-TECHZONE - IV,
 GREATER NOIDA

GOLDEN OCEAN INFRAHEIGHTS
 PROJECT
 PLOT NO. -11,
 SECTOR-TECHZONE-IV
 AT GREATER NOIDA WEST (U.P.)

SA
SIKKA ASSOCIATES ARCHITECTS
 A-401, AFYKA AMBIENCE, SPOKESMAN ROAD, NEW DELHI, INDIA 110009
 T: +91 11 4282 5335 | F: +91 11 2624 4448 | E: saasika@rediffmail.com | www.saasika.com



TOC +500	TOC -1200	TOC -1800	LVL - 4250	BACK TOP METAL ROAD	PAVER BLOCK ROAD
----------	-----------	-----------	------------	---------------------	------------------

ISSUED FOR

- INFORMATION & REVIEW
- SUBMISSION
- CONSTRUCTION DRAWING
- TENDER
- GPC
- AS BUILT

REVISIONS

#	DATE	DESCRIPTION

SCALE 1:500 @ A1

DATE ISSUED 10/09/2021

DRAWN BY T.G. RAWAT

CHECKED BY M. NAFEEB

SITE PLAN
SUB-SOIL DRAINAGE LAYOUT

PROJECT NO. CO/PC/G-1/MP/101A