

Mummy Floor

Terrace Floor

2nd Floor

1st Floor

Ground level

Basement level

HEAT PUMP / STORAGE TANK

LEGEND:-

- DOMESTIC WATER SUPPLY LINE
- HOT WATER SUPPLY LINE
- HOT WATER SUPPLY RETURN LINE
- VALVE
- NON RETURN VALVE (N.R.V)

KEY PLAN

HEAT PUMP

GENERAL NOTES:

- ALL DIMENSIONS ARE IN MM, UNLESS OTHERWISE MENTIONED.
- NO DIMENSIONS TO BE SCALED OR MEASURED FROM THIS DRG.
- CONTRACTOR MUST VERIFY ALL DIMENSION ON SITE & IF SOME DISCREPANCY FOUND SHALL BRING TO THE NOTICE.
- ALL BRICKWORK COVERING PIPES/ SERVICE DUCT WILL BE DONE AFTER INSTALLATION OF PIPES.
- CONTRACTOR MUST CHECK DIMENSIONS, LEVELS AND HEIGHTS W.R.T BENCHMARKING AT SITE AND INFORM IMMEDIATELY TO THE ARCHITECT IN CASE OF ANY DISCREPANCIES ARE NOTICED.
- ENSURE COMPLIANCE WITH ALL LOCAL BYE-LAWS, FIRE CODES AS WELL AS NBC.
- CONFLUENCE SHALL NOT BE RESPONSIBLE OR LIABLE FOR ANY DEVIATION IN ANY RESPECT INCLUDING CHANGE IN DESIGN, VISUAL INTENT, SPECIFICATION OR CONSTRUCTION METHODOLOGY ETC. MADE WITHOUT SPECIFIC WRITTEN APPROVAL FROM CONFLUENCE.
- ANY ERRORS, DISCREPANCIES, OMISSIONS, ALTERATIONS, MODIFICATIONS, CHANGES IN DESIGN SPECIFICATION DUE TO SITE CONDITIONS TO BE REPORTED TO THE ARCHITECT IMMEDIATELY FOR CLARIFICATIONS BEFORE EXECUTION OF WORK.
- NO ALTERATIONS TO DESIGN SPECIFICATIONS BE MADE WITHOUT PRIOR CONSENT OF THE ARCHITECT.
- ALL SAMPLES / MATERIALS TO BE APPROVED BY CONFLUENCE PRIOR EXECUTION OF INTERIORS WORKS AT SITE AND IN THIS REGARD A SAMPLE BOARD TO BE PREPARED BY CONTRACTOR AND HAS TO GET APPROVED FROM CONFLUENCE PRIOR TO EXECUTION.
- ALL RCC WORK AS/STR. DRG. ONLY.
- THE REINFORCEMENT SHALL BE PROVIDED IN ALL THE SERVICES SHAFTS (ELECTRICAL, LOW VOLTAGE, FHC ETC.) AND SHALL BE CAST AFTER INSTALLATION OF ALL THE REQUIRED SERVICES CONDUITS, SLEEVES, CABLES/ CABLE TRAYS/ CABLE LADDERS FOR FIRE COMPARTMENTATION REASON AS PER NBC 2016, PART-4 CLAUSE NUMBER 3.4.8.3. (FOR FIRE RATING OF WALL ENCLOSURE & FIRE RATING OF FIRE DOORS) & CLAUSE NO. C-1.9 'SERVICE DUCTS/SHAFTS'. ALL THE TOILET CUTOUTS FOR FLOOR TRAPS AND WC TRAPS SHALL BE CAST AFTER LAYING ALL THE REQUIRED PLUMBING PIPES. ALL THE INTERNAL PLUMBING SHAFT SHALL ALSO BE CLOSED AS PER AFORESAID CLAUSE BARING THE PERIPHERAL PLUMBING SHAFT. THESE PERIPHERAL SHAFTS SHALL BE PROVIDED WITH CAT-WALK FOR MAINTENANCE REASONS.
- ALL LEVELS ARE FROM + 96.480 LVL. WHICH IS CONSIDERED AS ± 0.00 LVL. UNLESS OTHERWISE MENTIONED.

REVISION	DATE	DESCRIPTION	BY
----------	------	-------------	----

THIS DRAWING IS A "COPYRIGHT" CONTENT OF THIS DRAWING OR PART THERE OF MAY NOT BE USED OR REPRODUCED WITHOUT THE PERMISSION OF THE ARCHITECT.

DRAWING FOR :-

- FOR SITE CO-ORDINATION ☐
- FOR TENDER PURPOSE ☐
- FOR APPROVAL ONLY ☒
- FOR ADVANCE COPY ☐
- GOOD FOR CONSTRUCTION ☐

CLIENT

GULSHAN HOMZ

GULSHAN DYNASTY,
MORADBAD

DATE	PROJECT INCHARGE	CHECKED BY
27.06.2023	NAFEES	ANIL
SCALE	DEALT BY	APPROVED BY
N/A	T.S.RAWAT	NAFEES

DRAWING TITLE

UNIT
WATER SUPPLY SLD

CONSULTANTS

STRUCTURE :	YG Consulting & Engineers LLP
ELECTRICAL :	Paradise Consultants
PLUMBING & FIRE FIGHTING :	Paradise Consultants
HVAC :	Paradise Consultants
LANDSCAPE:	CONFLUENCE

ARCHITECT:

Confluence
NEW DELHI , INDIA

B-421, NFC Ph- 01-11-20025684 cco@confluence.com Member of IGBC

110-651100A Ph- 01-11-4064798 www.confluence.com ISO - 9001 - 2005

architecture urban design hospitality interiors

DRAWING NO. AR-RERA-GH-MR-UN-PL-001

REVISION

R0

PLUMBING