		Area per					<u> </u>		
S.N.	Item Description	flat in sq mt	Unit	Qty	Load per sq mt in W	Load in KW	Total Load in KW	Diversity	Maximum load in kw
Α.	Pocket 1								
1	Plot	83.57	No.	58	50W	4.18 KW	242.35 KW	50%	121.18 KV
В.	Pocket 2								
1	Plot	126.0	No.	52	50W	6.30 KW	327.60 KW	50%	163.80 KV
C.	Pocket 3 Plot	126.0	No.	28	50W	6.30 KW	176.40 KW	50%	88.20 KV
D.	Pocket 4	120.0	INO.	20	3000	0.30 KVV	170.40 KVV	30%	00.20 KV
1	Plot	167.20	No.	60	50W	8.36 KW	501.60 KW	50%	250.80 KV
Ē.	STP	101.20	110.			50.00 KW	50.00 KW	80%	40.00 KV
F.	Street Lights+Landscape lights		No.	1		5.00 KW	5.00 KW	80%	4.00 KV
	DG SELECTION								
	Total load in KW CONSIDERING 70% OVERALL DIVERSITY								467.58 KV
	Total load in KVA considering 0.8 PF								584.48 KV
	DG capacity in KVA assuming 85% loading								687.62 KV
		nce we pr	opose	to insta	II 1 Nos 750 k	(VA DG SET			
	Cricket Academy					50.00 KW	50.00 KW	75%	37.50 KV
A. B.	Cricket Academy R-1 commercial area	6550	No.	1	150W	982.50 KW	982.50 KW	75%	736.88 KV
	R-1 senior citizen homes	6550	No.	1	50W	327.50 KW	327.50 KW	50%	163.75 KV
	R-2 Pro Shop , Food & Beverages	510	No.	1	150W	76.50 KW	76.50 KW	75%	57.38 KV
E.	R-3 R-2 Pro Shop , Food &	3570	No.	1	150W	535.50 KW	535.50 KW	75%	401.63 KV
F.	Beverages & Office at 4 th Floor	7050	No	1	150\\\	1117 50 1/1/	1117 50 1/1/	750/	960 62 17
	R-5 Club Tennis Center, Gymnastics, Badminton, Multi Purpose Hall	7650	No.	'	150W	1147.50 KW	1147.50 KW	75%	860.63 KV
G.	COMMERCIAL AREA	4047	No.	1	150W	607.05 KW	607.05 KW	75%	455.29 KV
H.	Plumbing	1017	110.	 '	10000	50.00 KW	50.00 KW	80%	40.00 KV
J.	Street Lights+Landscape lights		No.	1	10000W	10.00 KW	10.00 KW	80%	8.00 KV
K.	Fire fighting pumps					200.00 KW	200.00 KW	10%	20.00 KV
	DG SELECTION								
	Total load in KW CONSIDERING 70% OVERALL DIVERSITY								1946.73 KV
	Total load in KVA considering 0.8 PF								2433.41 KV
	DG capacity in KVA assuming 85% loading								2862.83 KV
	Hence we p	ropose to	install 2	2 Nos 12	250 KVA & 1 N	los 380 KVA Do	G SETS		
Α.	R-4 Medicine Centre	7140	No.	1	150W	1071.00 KW	1071.00 KW	75%	803.25 KV
	DG SELECTION								
	Total load in KW CONSIDERING 80% OVERALL DIVERSITY								642.60 KV
	Total load in KVA considering 0.8 PF								803.25 KV
	DG capacity in KVA assuming 85% loading								945.00 KV

M/s AMETEK BUILDTECH INDIA PVT. LTD.

E SQUARE PLOT NO.-C 6, SECTOR-96 NOIDA



