



EXTERNAL PLUMBING DUAL PLUMBING NOTES:-	
S.NO.	DESCRIPTION
1.	ALL DIMENSIONS ARE IN MILLIMETERS UNLESS NOTED OTHERWISE.
2.	WRITTEN DIMENSIONS ARE TO BE FOLLOWED. DRAWINGS ARE NOT TO BE SCALED.
3.	PLEASE CO-ORDINATE THIS DRAWING WITH ALL OTHER RELEVANT DRAWINGS OF ALL THE SERVICES.
4.	ALL WATER SUPPLY LINES INCLUDED IRRIGATION LINES WORK SHALL BE CARRIED OUT IN HDPE PIPES OF CLASS-3, PE100 CONFORMING TO IS:- 4984
5.	ALL LINES SHOWING IN LAYOUT ARE CENTER LINES.
6.	ALL WATER SUPPLY LINES SHALL BE LAID 750mm BELOW FROM FINISH GROUND LEVEL.
7.	ALL BURIED PIPES SHALL BE TESTED FOR LEAKAGES AND STRAIGHTNESS AS PER SPECIFICATION.

S. No.	SYMBOL	DESCRIPTION
1.		RIISING MAIN LINE (FROM T&W TO U.G.T.)
2.		MUNICIPAL WATER SUPPLY PIPE LINE
3.		DOMESTIC WATER SUPPLY LINE
4.		FLUSHING WATER SUPPLY LINE
5.		IRRIGATION WATER SUPPLY LINE
6.		PROPOSED TUBE WELL
7.		MASONRY CHAMBER FOR ISOLATING VALVE

SIG. OF ARCHITECT