



- EXTERNAL PLUMBING DATA SCHEDULING NOTES:
1. ALL DIMENSIONS DESCRIBED IN THESE NOTES SHALL BE TO FACE UNLESS SPECIFIED OTHERWISE.
 2. ALL DIMENSIONS ARE TO BE FOLLOWED. DIMENSIONS ARE NOT TO BE SCALED.
 3. FIELD CONDITIONS MAY VARY. THIS DRAWING WITH ALL OTHER RELEVANT DRAWINGS OF ALL THE SERVICES.
 4. ALL WATER SUPPLY LINES SHALL BE CARRIED OUT IN PIPE PRESS OF CLASS 3.0 (PE-100) CONFORMING TO ISO SPECIFICATION.
 5. ALL LINES SHOWING IN DOTTED ARE CENTER LINES.
 6. ALL WATER SUPPLY LINES SHALL BE LAD 80mm B.C.M FROM FINISH GROUND LEVEL.
 7. ALL BARRER PRESS SHALL BE TESTED PER LOADINGS AND STRENGTHNESS AS PER SPECIFICATION.
 8. ALL DOMESTIC WATER SUPPLY PRESS DV AS PER DESIGN CHART.

S. No.	SYMBOL	DESCRIPTION
1.		WATER SUPPLY LINE
2.		FLOW DIRECTION

PROJECT
PLOTTED DEVELOPMENT AT
VRINDA ORCHID TOWNSHIP

DRAWING TITLE:
EXTERNAL
WATER SUPPLY LAYOUT

For OM BUILD COM
Partner