



NOTES :

1. Minimum height required for LT Panel Room shall be 3.6 meter clear below beams.
2. Cable tray shall be connected by 2 nos. 32 x 6 mm GI strip to Main LT panel.
3. Location of Common Services Panel of each Tower shall be finalized as per site requirement / condition.

rev. no.	date	revision

project
SAYA S CLASS
AT INDIRAPURAM, GHAZIABAD.

title
ELECTRICAL DRAWING

subtitle

drawing released for
☒ APPROVAL ☐ SUBMISSION
☐ ADVANCE COPY ☐ CONSTRUCTION

drg. no. **SAYA/ELEC/EXT-87** drawn by **M. Firoz**
scale **1 : 220 @ A1** designed by **Ataq Ur Rehman**
date **June, 2018** checked by **Anand Haseela**

architect:
ARCHITECT HAFEZ CONTRACTOR

services consultant
Consummate Engineering Services (P) Ltd.
cespl
Noida Office : B-87, Sector-67, Noida - 201 301
Tel : (0120) 6943590 (24 Lines)
Lko Office : F-105, Sunrise Parkside, Ghatigaon, Lucknow
e mail : mail@cespl.in, website : www.cespl.in