

**Electrical load Calculation - Group Housing "La Residentia"**  
**at Plot No. 06A, Tech Zone - 4 at Noida Extn.**

**SUBSTATION SUMMARY**

S.no	Description	Nos. of Unit							Total Load	kVA/Unit
<b>CALCULATION FOR TRANSFORMER</b>										
1	Phase - 01	1484					=	4760	KVA	3.21 kVA/Unit
2	Phase - 02	1772					=	5720	KVA	3.23 kVA/Unit
	<b>Total</b>	<b>3256</b>					=	<b>10480</b>	<b>KVA</b>	
<b>Recommended Transformers = Phase- 01 : - 4 nos 1600 KVA &amp; for Phase-02 : - 2 nos. 2000 KVA &amp; 2 nos. 1600 KVA</b>										
<b>CALCULATION FOR DG SETS</b>										
3	Phase - 01	1484					=	3880	KVA	2.61 kVA/Unit
4	Phase - 02	1772					=	4590	KVA	2.59 kVA/Unit
	<b>Total</b>	<b>3256</b>					=	<b>8470</b>	<b>KVA</b>	
<b>Recommended DG SETS = Phase- 01 : - 2 nos 1010 KVA &amp; 4 nos 500 KVA &amp; for Phase-02 : - 2 nos 1010 KVA &amp; 4 nos 750 KVA</b>										

<b>Electrical load Calculation - Group Housing "La Residentia"</b> <b>at Plot No. 06A, Tech Zone - 4 at Noida Extn.</b>											
<b>PHASE - 01</b>											
S.no	Description		No. of unit		Load per Unit			Total Load			
	<b>TOWER - 1 &amp; 7 (B+P+G+22)</b>		<b>Nos of Towers</b>		<b>=</b>	<b>2</b>					
1	4 BHK + 5 T + Servant (158 sq M @ 50 W/sqM = 7.90 KW)		184	units	@	7.90	KW		=	1454	KW
	<b>TOWER - 2, 14 &amp; 16 (B+P+G+18)</b>		<b>Nos of Towers</b>		<b>=</b>	<b>3</b>					
2	3 BHK + 2 T (Large) (104 sq M @ 50 W/sqM = 5.20 KW)		228	units	@	5.20	KW		=	1187	KW
	<b>TOWER - 3 &amp; 17 (B+P+G+18)</b>		<b>Nos of Towers</b>		<b>=</b>	<b>2</b>					
3	3 BHK + 3 T + Study (119 sq M @ 50 W/sqM = 5.95 KW)		76	units	@	5.95	KW		=	452	KW
4	3 BHK + 4 T + Servant (134 sq M @ 50 W/sqM = 6.70 KW)		76	units	@	6.70	KW		=	509	KW
	<b>TOWER - 4 (B+P+G+22)</b>		<b>Nos of Towers</b>		<b>=</b>	<b>1</b>					
5	2 BHK + 2T (82 sq M @ 50 W/sqM = 4.09 KW)		92	units	@	4.09	KW		=	376	KW
	<b>TOWER - 5, 6, 12, 15 &amp; 18 (B+P+G+18)</b>		<b>Nos of Towers</b>		<b>=</b>	<b>5</b>					
6	2 BHK + 2T + Study (79 sq M @ 50 W/sqM = 3.95 KW)		190	units	@	3.95	KW		=	750	KW
7	2 BHK + 2T (71 sq M @ 50 W/sqM = 3.54 KW)		190	units	@	3.54	KW		=	672	KW
	<b>TOWER - 8 &amp; 10 (B+P+G+13)</b>		<b>Nos of Towers</b>		<b>=</b>	<b>2</b>					
8	3 BHK + 2T (93 sq M @ 50 W/sqM = 4.66 KW)		112	units	@	4.66	KW		=	522	KW

S.no	Description		No. of unit		Load per Unit			Total Load			
	TOWER - 9 (B+P+G+22)		Nos of Towers			=	1				
9	3 BHK + 3 T + Study		46	units	@	5.95	KW		=	274	KW
	(119 sq M @ 50 W/sqM =	5.95 KW)									
10	3 BHK + 4 T + Servant		46	units	@	6.70	KW		=	308	KW
	(134 sq M @ 50 W/sqM =	6.70 KW)									
	TOWER - 11 (B+P+G+22)		Nos of Towers			=	1				
11	2 BHK + 2T + Study		46	units	@	3.95	KW		=	182	KW
	(79 sq M @ 50 W/sqM =	3.95 KW)									
12	2 BHK + 2T		46	units	@	3.54	KW		=	163	KW
	(71 sq M @ 50 W/sqM =	3.54 KW)									
	TOWER - 13 & 19 (B+P+G+18)		Nos of Towers			=	2				
13	3 BHK + 2T		152	units	@	4.66	KW		=	708	KW
	(93 sq M @ 50 W/sqM =	4.66 KW)									
	COMMON SERVICES - TOWERS										
	TOWER - 1 & 7 (B+P+G+22)		Nos of Towers			=	2				
14	Elevators (13 Passenger) 1.5 mps		2	nos	@	10.0	KW		=	20	KW
15	Elevators (16 Passenger) 1.5 mps		2	nos	@	15.0	KW		=	30	KW
16	Common Lights		2	towers	@	5.0	KW		=	10	KW
	TOWER - 2, 14 & 16 (B+P+G+18)		Nos of Towers			=	3				
17	Elevators (13 Passenger) 1.5 mps		3	nos	@	10.0	KW		=	30	KW
18	Elevators (16 Passenger) 1.5 mps		3	nos	@	15.0	KW		=	45	KW
19	Common Lights		3	towers	@	3.0	KW		=	9	KW
	TOWER - 3 & 17 (B+P+G+18)		Nos of Towers			=	2				
20	Elevators (13 Passenger) 1.5 mps		2	nos	@	10.0	KW		=	20	KW
21	Elevators (16 Passenger) 1.5 mps		2	nos	@	15.0	KW		=	30	KW
22	Common Lights		2	towers	@	4.0	KW		=	8	KW

S.no	Description	No. of unit			Load per Unit			Total Load		
	<b>TOWER - 4 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
23	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW	=	10	KW	
24	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW	=	15	KW	
25	Common Lights	1	towers	@	4.0	KW	=	4	KW	
	<b>TOWER - 5, 6, 12, 15 &amp; 18 (B+P+G+18)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>5</b>				
26	Elevators (13 Passenger) 1.5 mps	5	nos	@	10.0	KW	=	50	KW	
27	Elevators (16 Passenger) 1.5 mps	5	nos	@	15.0	KW	=	75	KW	
28	Common Lights	5	towers	@	3.0	KW	=	15	KW	
	<b>TOWER - 8 &amp; 10 (B+P+G+13)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>2</b>				
29	Elevators (13 Passenger) 1.0 mps	2	nos	@	7.0	KW	=	14	KW	
30	Elevators (16 Passenger) 1.0 mps	2	nos	@	9.0	KW	=	18	KW	
31	Common Lights	2	towers	@	3.0	KW	=	6	KW	
	<b>TOWER - 9 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
32	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW	=	10	KW	
33	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW	=	15	KW	
34	Common Lights	1	towers	@	5.0	KW	=	5	KW	
	<b>TOWER - 11 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
35	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW	=	10	KW	
36	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW	=	15	KW	
37	Common Lights	1	towers	@	4.0	KW	=	4	KW	
	<b>TOWER - 13 &amp; 19 (B+P+G+18)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>2</b>				
38	Elevators (13 Passenger) 1.5 mps	2	nos	@	10.0	KW	=	20	KW	
39	Elevators (16 Passenger) 1.5 mps	2	nos	@	15.0	KW	=	30	KW	
40	Common Lights	2	towers	@	4.0	KW	=	8	KW	

S.no	Description	No. of unit		Load per Unit				Total Load		
	<b><u>COMMON SERVICES - General</u></b>									
41	External / Gate / Landscape lighting							=	10	KW
42	Basement lights	33500	sqm	@	1.0	W/sqm		=	34	KW
43	Basement Ventillation							=	200	KW
44	Club / Swimming pool							=	250	KW
				<b>Total Load</b>				<b>=</b>	<b>8576</b>	<b>KW</b>
<b>By taking Overall Diversity factor</b>						<b>50 %</b>		<b>=&gt;</b>	<b>4288</b>	<b>KW</b>
<b>By taking Power factor</b>						<b>0.90</b>		<b>=&gt;</b>	<b>4760</b>	<b>KVA</b>
<b>Total Electrical Load (Phase-01) = 4760 KVA</b>										
<b>Recommended Transformers (at 85% loading) = 2 nos. 1600 KVA each at 2 different locations.</b> <b>(Total 4 nos 1600 KVA each)</b>										

<b>Electrical load Calculation - Group Housing "La Residentia"</b> <b>at Plot No. 06A, Tech Zone - 4 at Noida Extn.</b>											
<b>PHASE - 02</b>											
<b>S.no</b>	<b>Description</b>		<b>No. of unit</b>		<b>Load per Unit</b>			<b>Total Load</b>			
	<b>TOWER - 20, 22, 24, 27 &amp; 32 (B+P+G+22)</b>		<b>Nos of Towers</b>		<b>=</b>	<b>5</b>					
1	2 BHK + 2T + Study		230	units	@	3.95	KW		=	908	KW
	(79 sq M @ 50 W/sqM = 3.95 KW)										
2	2 BHK + 2T		230	units	@	3.54	KW		=	813	KW
	(71 sq M @ 50 W/sqM = 3.54 KW)										
	<b>TOWER - 21 &amp; 23 (B+P+G+22)</b>		<b>Nos of Towers</b>		<b>=</b>	<b>2</b>					
3	3 BHK + 3 T + Study		92	units	@	5.95	KW		=	547	KW
	(119 sq M @ 50 W/sqM = 5.95 KW)										
4	3 BHK + 4 T + Servant		92	units	@	6.70	KW		=	616	KW
	(134 sq M @ 50 W/sqM = 6.70 KW)										
	<b>TOWER - 25 (B+P+G+22)</b>		<b>Nos of Towers</b>		<b>=</b>	<b>1</b>					
5	3 BHK + 2 T (Large)		92	units	@	5.20	KW		=	479	KW
	(104 sq M @ 50 W/sqM = 5.20 KW)										
	<b>TOWER - 26, 29 &amp; 30 (B+P+G+22)</b>		<b>Nos of Towers</b>		<b>=</b>	<b>3</b>					
6	3 BHK + 2T		276	units	@	4.66	KW		=	1286	KW
	(93 sq M @ 50 W/sqM = 4.66 KW)										
	<b>TOWER - 28 &amp; 31 (B+P+G+22)</b>		<b>Nos of Towers</b>		<b>=</b>	<b>2</b>					
7	2 BHK + 2T		184	units	@	4.09	KW		=	752	KW
	(82 sq M @ 50 W/sqM = 4.09 KW)										
	<b>TOWER - 33 (B+P+G+18)</b>		<b>Nos of Towers</b>		<b>=</b>	<b>1</b>					
8	2 BHK + 2T + Study		76	units	@	3.95	KW		=	300	KW
	(79 sq M @ 50 W/sqM = 3.95 KW)										

S.no	Description		No. of unit		Load per Unit			Total Load			
	TOWER - 34 (B+P+G+20)		Nos of Towers			=	1				
9	3 BHK + 3 T + Study		42	units	@	5.95	KW		=	250	KW
	(119 sq M @ 50 W/sqM =	5.95 KW)									
10	3 BHK + 4 T + Servant		42	units	@	6.70	KW		=	281	KW
	(134 sq M @ 50 W/sqM =	6.70 KW)									
	TOWER - 35 (B+P+G+18)		Nos of Towers			=	1				
11	2 BHK + 2T + Study		38	units	@	3.95	KW		=	150	KW
	(79 sq M @ 50 W/sqM =	3.95 KW)									
12	2 BHK + 2T		38	units	@	3.54	KW		=	134	KW
	(71 sq M @ 50 W/sqM =	3.54 KW)									
	TOWER - 36 (B+P+G+21)		Nos of Towers			=	1				
13	3 BHK + 3 T + Study		44	units	@	5.95	KW		=	262	KW
	(119 sq M @ 50 W/sqM =	5.95 KW)									
14	3 BHK + 4 T + Servant		44	units	@	6.70	KW		=	295	KW
	(134 sq M @ 50 W/sqM =	6.70 KW)									
	TOWER - 37 (B+P+G+18)		Nos of Towers			=	1				
15	3 BHK + 2 T (Large)		76	units	@	5.20	KW		=	396	KW
	(104 sq M @ 50 W/sqM =	5.20 KW)									
	TOWER - 38 (B+P+G+20)		Nos of Towers			=	1				
16	3 BHK + 2 T (Large)		84	units	@	5.20	KW		=	437	KW
	(104 sq M @ 50 W/sqM =	5.20 KW)									
	TOWER - 39 (B+P+G+22)		Nos of Towers			=	1				
17	4 BHK + 5 T + Servant		92	units	@	7.90	KW		=	727	KW
	(158 sq M @ 50 W/sqM =	7.90 KW)									

S.no	Description	No. of unit			Load per Unit			Total Load		
	<b>COMMON SERVICES - TOWERS</b>									
	<b>TOWER - 20, 22, 24, 27 &amp; 32 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>5</b>				
18	Elevators (13 Passenger) 1.5 mps	5	nos	@	10.0	KW		=	50	KW
19	Elevators (16 Passenger) 1.5 mps	5	nos	@	15.0	KW		=	75	KW
20	Common Lights	5	towers	@	4.0	KW		=	20	KW
	<b>TOWER - 21 &amp; 23 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>2</b>				
21	Elevators (13 Passenger) 1.5 mps	2	nos	@	10.0	KW		=	20	KW
22	Elevators (16 Passenger) 1.5 mps	2	nos	@	15.0	KW		=	30	KW
23	Common Lights	2	towers	@	5.0	KW		=	10	KW
	<b>TOWER - 25 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
24	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW		=	10	KW
25	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW		=	15	KW
26	Common Lights	1	towers	@	4.0	KW		=	4	KW
	<b>TOWER - 26, 29 &amp; 30 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>3</b>				
27	Elevators (13 Passenger) 1.5 mps	3	nos	@	10.0	KW		=	30	KW
28	Elevators (16 Passenger) 1.5 mps	3	nos	@	15.0	KW		=	45	KW
29	Common Lights	3	towers	@	5.0	KW		=	15	KW
	<b>TOWER - 28 &amp; 31 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>2</b>				
30	Elevators (13 Passenger) 1.5 mps	2	nos	@	10.0	KW		=	20	KW
31	Elevators (16 Passenger) 1.5 mps	2	nos	@	15.0	KW		=	30	KW
32	Common Lights	2	towers	@	4.0	KW		=	8	KW
	<b>TOWER - 33 (B+P+G+18)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
33	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW		=	10	KW
34	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW		=	15	KW
35	Common Lights	1	towers	@	3.0	KW		=	3	KW



S.no	Description	No. of unit			Load per Unit			Total Load		
	<b>TOWER - 34 (B+P+G+20)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
36	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW	=	10	KW	
37	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW	=	15	KW	
38	Common Lights	1	towers	@	4.0	KW	=	4	KW	
	<b>TOWER - 35 (B+P+G+18)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
39	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW	=	10	KW	
40	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW	=	15	KW	
41	Common Lights	1	towers	@	3.0	KW	=	3	KW	
	<b>TOWER - 36 (B+P+G+21)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
42	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW	=	10	KW	
43	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW	=	15	KW	
44	Common Lights	1	towers	@	5.0	KW	=	5	KW	
	<b>TOWER - 37 (B+P+G+18)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
45	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW	=	10	KW	
46	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW	=	15	KW	
47	Common Lights	1	towers	@	3.0	KW	=	3	KW	
	<b>TOWER - 38 (B+P+G+20)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
48	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW	=	10	KW	
49	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW	=	15	KW	
50	Common Lights	1	towers	@	4.0	KW	=	4	KW	
	<b>TOWER - 39 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
51	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW	=	10	KW	
52	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW	=	15	KW	
53	Common Lights	1	towers	@	5.0	KW	=	5	KW	

S.no	Description	No. of unit		Load per Unit				Total Load		
	<b><u>COMMON SERVICES - General</u></b>									
54	Tube wells / Water Supply Pumps							=	200	KW
55	STP								200	KW
56	External / Gate / Landscape lighting							=	10	KW
57	Basement lights	37700	sqm	@	1.0	W/sqm		=	38	KW
58	Basement Ventillation							=	300	KW
59	Commercial etc							=	300	KW
60	Fire pumps (only jockey pumps have been considered)	2	set	@	15	KW		=	30	KW
				<b>Total Load</b>				<b>=</b>	<b>10297</b>	<b>KW</b>
<b>By taking Overall Diversity factor</b>						<b>50 %</b>		<b>=&gt;</b>	<b>5148</b>	<b>KW</b>
<b>By taking Power factor</b>						<b>0.90</b>		<b>=&gt;</b>	<b>5720</b>	<b>KVA</b>
<b>Total Electrical Load (Phase-02) = 5720 KVA</b>										
<b>Recommended Transformers (at 85% loading) = 2 nos. 2000 KVA &amp; 2 nos. 1600 KVA.</b>										

Essential Electrical load Calculation - Group Housing "La Residentia"											
at Plot No. 06A, Tech Zone - 4 at Noida Extn.											
PHASE - 01											
S.no	Description			No. of unit		Load per Unit			Total Load		
	TOWER - 1 &7 (B+P+G+22)		Nos of Towers			=	2				
1	4 BHK + 5 T + Servant			184	units	@	3.00	KW		=	552 KW
	TOWER - 2, 14 & 16 (B+P+G+18)		Nos of Towers			=	3				
2	3 BHK + 2 T (Large)			228	units	@	2.00	KW		=	456 KW
	TOWER - 3 & 17 (B+P+G+18)		Nos of Towers			=	2				
3	3 BHK + 3 T + Study			76	units	@	2.00	KW		=	152 KW
4	3 BHK + 4 T + Servant			76	units	@	2.00	KW		=	152 KW
	TOWER - 4 (B+P+G+22)		Nos of Towers			=	1				
5	2 BHK + 2T			92	units	@	1.00	KW		=	92 KW
	TOWER - 5, 6, 12, 15 & 18 (B+P+G+18)		Nos of Towers			=	5				
6	2 BHK + 2T + Study			190	units	@	1.00	KW		=	190 KW
7	2 BHK + 2T			190	units	@	1.00	KW		=	190 KW
	TOWER - 8 & 10 (B+P+G+13)		Nos of Towers			=	2				
8	3 BHK + 2T			112	units	@	2.00	KW		=	224 KW
	TOWER - 9 (B+P+G+22)		Nos of Towers			=	1				
9	3 BHK + 3 T + Study			46	units	@	2.00	KW		=	92 KW
10	3 BHK + 4 T + Servant			46	units	@	2.00	KW		=	92 KW
	TOWER - 11 (B+P+G+22)		Nos of Towers			=	1				
11	2 BHK + 2T + Study			46	units	@	1.00	KW		=	46 KW
12	2 BHK + 2T			46	units	@	1.00	KW		=	46 KW
	TOWER - 13 & 19 (B+P+G+18)		Nos of Towers			=	2				
13	3 BHK + 2T			152	units	@	2.00	KW		=	304 KW
							Total Load =			2588	KW
By taking Overall Diversity factor							100	%	=>	2588	KW
By taking Power factor							0.80		=>	3240	KVA
Essential Load ( A )							=	3240			KVA

S.no	Description	No. of unit			Load per Unit			Total Load		
	<b>COMMON SERVICES - TOWERS</b>									
	<b>TOWER - 1 &amp; 7 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>2</b>				
14	Elevators (13 Passenger) 1.5 mps	2	nos	@	10.0	KW	=	20	KW	
15	Elevators (16 Passenger) 1.5 mps	2	nos	@	15.0	KW	=	30	KW	
16	Common Lights	2	towers	@	5.0	KW	=	10	KW	
	<b>TOWER - 2, 14 &amp; 16 (B+P+G+18)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>3</b>				
17	Elevators (13 Passenger) 1.5 mps	3	nos	@	10.0	KW	=	30	KW	
18	Elevators (16 Passenger) 1.5 mps	3	nos	@	15.0	KW	=	45	KW	
19	Common Lights	3	towers	@	3.0	KW	=	9	KW	
	<b>TOWER - 3 &amp; 17 (B+P+G+18)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>2</b>				
20	Elevators (13 Passenger) 1.5 mps	2	nos	@	10.0	KW	=	20	KW	
21	Elevators (16 Passenger) 1.5 mps	2	nos	@	15.0	KW	=	30	KW	
22	Common Lights	2	towers	@	4.0	KW	=	8	KW	
	<b>TOWER - 4 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
23	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW	=	10	KW	
24	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW	=	15	KW	
25	Common Lights	1	towers	@	4.0	KW	=	4	KW	
	<b>TOWER - 5, 6, 12, 15 &amp; 18 (B+P+G+18)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>5</b>				
26	Elevators (13 Passenger) 1.5 mps	5	nos	@	10.0	KW	=	50	KW	
27	Elevators (16 Passenger) 1.5 mps	5	nos	@	15.0	KW	=	75	KW	
28	Common Lights	5	towers	@	3.0	KW	=	15	KW	
	<b>TOWER - 8 &amp; 10 (B+P+G+13)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>2</b>				
29	Elevators (13 Passenger) 1.0 mps	2	nos	@	7.0	KW	=	14	KW	
30	Elevators (16 Passenger) 1.0 mps	2	nos	@	9.0	KW	=	18	KW	
31	Common Lights	2	towers	@	3.0	KW	=	6	KW	

S.no	Description		No. of unit		Load per Unit			Total Load		
	TOWER - 9 (B+P+G+22)		Nos of Towers		=	1				
32	Elevators (13 Passenger) 1.5 mps		1	nos	@	10.0	KW	=	10	KW
33	Elevators (16 Passenger) 1.5 mps		1	nos	@	15.0	KW	=	15	KW
34	Common Lights		1	towers	@	5.0	KW	=	5	KW
	TOWER - 11 (B+P+G+22)		Nos of Towers		=	1				
35	Elevators (13 Passenger) 1.5 mps		1	nos	@	10.0	KW	=	10	KW
36	Elevators (16 Passenger) 1.5 mps		1	nos	@	15.0	KW	=	15	KW
37	Common Lights		1	towers	@	4.0	KW	=	4	KW
	TOWER - 13 & 19 (B+P+G+18)		Nos of Towers		=	2				
38	Elevators (13 Passenger) 1.5 mps		2	nos	@	10.0	KW	=	20	KW
39	Elevators (16 Passenger) 1.5 mps		2	nos	@	15.0	KW	=	30	KW
40	Common Lights		2	towers	@	4.0	KW	=	8	KW
	<u>COMMON SERVICES - General</u>									
41	External / Gate / Landscape lighting							=	10	KW
42	Basement lights	33500	sqm	@	1.0	W/sqm		=	34	KW
43	Basement Ventillation							=	200	KW
44	Club / Swimming pool							=	250	KW
						Total Load		=	1020	KW
By taking Overall Diversity factor							50 %	=>	510	KW
By taking Power factor							0.80	=>	640	KVA
Essential Load ( B )							=	640		KVA
	Total Essential Load : Phase-01 ( A + B )				=	3880	KVA			
Recommended DG Sets at 95% loading = 1 nos 1010 KVA and 2 nos. 500 KVA at 2 different location. (Total 2 nos 1010 KVA & 4 nos 500 KVA)										

<b><u>Essential Electrical load Calculation - Group Housing "La Residentia"</u></b> <b><u>at Plot No. 06A, Tech Zone - 4 at Noida Extn.</u></b>											
<b><u>PHASE - 02</u></b>											
S.no	Description			No. of unit			Load per Unit			Total Load	
	<b>TOWER - 20, 22, 24, 27 &amp; 32 (B+P+G+22)</b>			<b>Nos of Towers</b>			<b>=</b>	<b>5</b>			
1	2 BHK + 2T + Study			230	units	@	1.00	KW		=	230 KW
2	2 BHK + 2T			230	units	@	1.00	KW		=	230 KW
	<b>TOWER - 21 &amp; 23 (B+P+G+22)</b>			<b>Nos of Towers</b>			<b>=</b>	<b>2</b>			
3	3 BHK + 3 T + Study			92	units	@	2.00	KW		=	184 KW
4	3 BHK + 4 T + Servant			92	units	@	2.00	KW		=	184 KW
	<b>TOWER - 25 (B+P+G+22)</b>			<b>Nos of Towers</b>			<b>=</b>	<b>1</b>			
5	3 BHK + 2 T (Large)			92	units	@	2.00	KW		=	184 KW
	<b>TOWER - 26, 29 &amp; 30 (B+P+G+22)</b>			<b>Nos of Towers</b>			<b>=</b>	<b>3</b>			
6	3 BHK + 2T			276	units	@	2.00	KW		=	552 KW
	<b>TOWER - 28 &amp; 31 (B+P+G+22)</b>			<b>Nos of Towers</b>			<b>=</b>	<b>2</b>			
7	2 BHK + 2T			184	units	@	1.00	KW		=	184 KW
	<b>TOWER - 33 (B+P+G+18)</b>			<b>Nos of Towers</b>			<b>=</b>	<b>1</b>			
8	2 BHK + 2T + Study			76	units	@	1.00	KW		=	76 KW
	<b>TOWER - 34 (B+P+G+20)</b>			<b>Nos of Towers</b>			<b>=</b>	<b>1</b>			
9	3 BHK + 3 T + Study			42	units	@	2.00	KW		=	84 KW
10	3 BHK + 4 T + Servant			42	units	@	2.00	KW		=	84 KW
	<b>TOWER - 35 (B+P+G+18)</b>			<b>Nos of Towers</b>			<b>=</b>	<b>1</b>			
11	2 BHK + 2T + Study			38	units	@	1.00	KW		=	38 KW
12	2 BHK + 2T			38	units	@	1.00	KW		=	38 KW
	<b>TOWER - 36 (B+P+G+21)</b>			<b>Nos of Towers</b>			<b>=</b>	<b>1</b>			
13	3 BHK + 3 T + Study			44	units	@	2.00	KW		=	88 KW
14	3 BHK + 4 T + Servant			44	units	@	2.00	KW		=	88 KW

S.no	Description	No. of unit			Load per Unit			Total Load		
	<b>TOWER - 37 (B+P+G+18)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
15	3 BHK + 2 T (Large)	76	units	@	2.00	KW		=	152	KW
	<b>TOWER - 38 (B+P+G+20)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
16	3 BHK + 2 T (Large)	84	units	@	2.00	KW		=	168	KW
	<b>TOWER - 39 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
17	4 BHK + 5 T + Servant	92	units	@	3.00	KW		=	276	KW
					<b>Total Load</b>			<b>=</b>	<b>2840</b>	<b>KW</b>
<b>By taking Overall Diversity factor</b>						<b>100 %</b>	<b>=&gt;</b>		<b>2840</b>	<b>KW</b>
<b>By taking Power factor</b>						<b>0.80</b>	<b>=&gt;</b>		<b>3550</b>	<b>KVA</b>
<b>Essential Load ( A )</b>						<b>=</b>			<b>3550</b>	<b>KVA</b>
	<b><u>COMMON SERVICES - TOWERS</u></b>									
	<b>TOWER - 20, 22, 24, 27 &amp; 32 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>5</b>				
18	Elevators (13 Passenger) 1.5 mps	5	nos	@	10.0	KW		=	50	KW
19	Elevators (16 Passenger) 1.5 mps	5	nos	@	15.0	KW		=	75	KW
20	Common Lights	5	towers	@	4.0	KW		=	20	KW
	<b>TOWER - 21 &amp; 23 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>2</b>				
21	Elevators (13 Passenger) 1.5 mps	2	nos	@	10.0	KW		=	20	KW
22	Elevators (16 Passenger) 1.5 mps	2	nos	@	15.0	KW		=	30	KW
23	Common Lights	2	towers	@	5.0	KW		=	10	KW
	<b>TOWER - 25 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
24	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW		=	10	KW
25	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW		=	15	KW
26	Common Lights	1	towers	@	4.0	KW		=	4	KW

S.no	Description	No. of unit			Load per Unit			Total Load		
	<b>TOWER - 26, 29 &amp; 30 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>3</b>				
27	Elevators (13 Passenger) 1.5 mps	3	nos	@	10.0	KW		=	30	KW
28	Elevators (16 Passenger) 1.5 mps	3	nos	@	15.0	KW		=	45	KW
29	Common Lights	3	towers	@	5.0	KW		=	15	KW
	<b>TOWER - 28 &amp; 31 (B+P+G+22)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>2</b>				
30	Elevators (13 Passenger) 1.5 mps	2	nos	@	10.0	KW		=	20	KW
31	Elevators (16 Passenger) 1.5 mps	2	nos	@	15.0	KW		=	30	KW
32	Common Lights	2	towers	@	4.0	KW		=	8	KW
	<b>TOWER - 33 (B+P+G+18)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
33	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW		=	10	KW
34	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW		=	15	KW
35	Common Lights	1	towers	@	3.0	KW		=	3	KW
	<b>TOWER - 34 (B+P+G+20)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
36	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW		=	10	KW
37	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW		=	15	KW
38	Common Lights	1	towers	@	4.0	KW		=	4	KW
	<b>TOWER - 35 (B+P+G+18)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
39	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW		=	10	KW
40	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW		=	15	KW
41	Common Lights	1	towers	@	3.0	KW		=	3	KW
	<b>TOWER - 36 (B+P+G+21)</b>	<b>Nos of Towers</b>			<b>=</b>	<b>1</b>				
42	Elevators (13 Passenger) 1.5 mps	1	nos	@	10.0	KW		=	10	KW
43	Elevators (16 Passenger) 1.5 mps	1	nos	@	15.0	KW		=	15	KW
44	Common Lights	1	towers	@	5.0	KW		=	5	KW



S.no	Description		No. of unit			Load per Unit			Total Load		
	TOWER - 37 (B+P+G+18)		Nos of Towers			=	1				
45	Elevators (13 Passenger) 1.5 mps		1	nos	@	10.0	KW		=	10	KW
46	Elevators (16 Passenger) 1.5 mps		1	nos	@	15.0	KW		=	15	KW
47	Common Lights		1	towers	@	3.0	KW		=	3	KW
	TOWER - 38 (B+P+G+20)		Nos of Towers			=	1				
48	Elevators (13 Passenger) 1.5 mps		1	nos	@	10.0	KW		=	10	KW
49	Elevators (16 Passenger) 1.5 mps		1	nos	@	15.0	KW		=	15	KW
50	Common Lights		1	towers	@	4.0	KW		=	4	KW
	TOWER - 39 (B+P+G+22)		Nos of Towers			=	1				
51	Elevators (13 Passenger) 1.5 mps		1	nos	@	10.0	KW		=	10	KW
52	Elevators (16 Passenger) 1.5 mps		1	nos	@	15.0	KW		=	15	KW
53	Common Lights		1	towers	@	5.0	KW		=	5	KW
	<u>COMMON SERVICES - General</u>										
54	Tube wells / Water Supply Pumps								=	200	KW
55	STP									200	KW
56	External / Gate / Landscape lighting								=	10	KW
57	Basement lights	37700	sqm	@	1.0	W/sqm			=	38	KW
58	Basement Ventillation								=	300	KW
59	Commercial etc								=	300	KW
60	Fire pumps (only jockey pumps have been considered)		2	set	@	15	KW		=	30	KW
						Total Load			=	1662	KW
By taking Overall Diversity factor							50	%	=>	831	KW
By taking Power factor							0.80		=>	1040	KVA
Essential Load ( B )							=	1040		KVA	
	Total Essential Load : Phase-02 ( A + B )				=	4590	KVA				
Recommended DG Sets at 95% loading = 1 nos 1010 KVA and 2 nos. 750 KVA at 2 different location. (Total 2 nos 1010 KVA & 4 nos 750 KVA)											