



Dated : 9/01/2006

579-GMMZ/17M/E-3

OFFICE MEMORANDUM

In reference to Deputy General Manager, Electricity Urban Distribution Circle, Moradabad's letter No.90/EUDC(M)/DS/Complex dated 06/01/2006 for electrification of Avas-Vikas Majhola No.4(Part-2)I-Phase, permission is hereby accorded for electrification with the following provisions:-

The load intimated by the Deputy General Manager, Electricity Urban Distribution Circle, Moradabad is approximately 40 MVA.

1-No. 132 KV Substation alongwith associated line(capacity 2x20 MVA)will be constructed at the cost of Avas-Vikas as per provisions of Distribution Code-2005.

2 No. 33/11 KV Substations with capacity 2x10=20 MVA each will be got constructed at the cost of Avas-Vikas alongwith associated lines.

Distribution System will be HVDS. *on the Cost of Avas Vikas*
 Since construction of 132 KV Substation will take time and if Avas-Vikas, in the meantime develop their colony and requires connections for 33 KV substations from some alternate source, that will be permitted on following grounds:-

a) It will be done after Avas-Vikas deposits the cost of 132 KV Substation and associated 132 KV Line.

b) The cost of providing alternate line will be borne by Avas-Vikas.

On Substations Quarters of Staff will be got constructed by the Avas-Vikas as per UP Power Corporation Limited norms.

In case Avas-Vikas desires to get works of 33 KV Substations and associated lines and also HVDS System, done themselves, the same shall be permitted to them. They will pay 15% supervision charges as per Distribution Code-2005.

Other charges like drawing and registration charges should be got deposited.

The Transformer to be arranged by Avas-Vikas will be of Standard make prevalent in UP Power Corporation Limited.

0- A tripartite type agreement among Avas-Vikas, Manufacturer of Transformer and Executive Engineer, Electricity Urban Distribution Division-I, Moradabad will be executed with the conditions that if any of the transformer supplied by Avas-Vikas is damaged within a period of 24 months, the same shall be replaced by the Builder free of cost.

11- H.T. T.V.M. will be got installed by Avas-Vikas on Transformers.

12- After completion of works by Avas-Vikas, permission for taking over will be given by the Deputy General Manager, Electricity Urban Distribution Circle, Moradabad.

13- In case of Independent Feeder, pilfer proof metering arrangement will also be done at the substation end.

No. 579-GMMZ/of date

P.K. GOEL
 GENERAL MANAGER

- 1- Copy forwarded to the Superintending Engineer(E&M)UP Avas-Vikas Parishad, Office Complex, Near Bhoot Nath Mandir, Indira Nagar, Lucknow for information & necessary action.
- 2- Copy forwarded to the Executive Engineer(E&M) Avas-Vikas Parishad, Office Complex, Near Bhoot Nath Mandir, Indira Nagar, Lucknow alongwith a copy of Map received from the Deputy General Manager, Electricity Urban Distribution Circle, Moradabad.

Encl:as above.

P.K. GOEL
 GENERAL MANAGER