



NOTES :

1. Minimum height required for LT Panel Room shall be 3.6 meter clear below beams.
2. Cable tray shall be connected by 2 nos. 32 x 6 mm GI strip to Main LT panel.
3. Location of Common Services Panel of each Tower shall be finalized as per site requirement / condition.

rev. no.	date	revision

project

SAYA S CLASS
AT INDRAPURAM, GHAZIABAD.

title

SITE PLAN

subtitle

drawing released for

- | | |
|---------------------------------------|---------------------------------------|
| <input type="checkbox"/> APPROVAL | <input type="checkbox"/> SUBMISSION |
| <input type="checkbox"/> ADVANCE COPY | <input type="checkbox"/> CONSTRUCTION |

drg. no. **SAYA/ELEC/EXT-87**

drawn by **M. Firoz**

scale **1: 220 @ A1**

designed by **Ataq Ur Rehman**

date **June, 2018**

checked by **Anand Hasnani**

architect:

ARCHITECT HAFEZ CONTRACTOR

services consultant

Consummate Engineering Services (P) Ltd.

Noida Office : B-87, Sector-67, Noida - 201 301
Tel : (0120) 6845500 (24 Lines)
Gurgaon Office : F-108, Sector-14, Gurgaon - 122 002
e mail : mail@cespl.in, website : www.cespl.in

cespl