

COMMON ESS, UGT & STP WITH OFFICER CITY 1

MEDIAN OF ROAD

PROPOSED 45.00 METER WIDE ROAD

TO RAJ NAGAR/MERUTH ROAD >>>

MEDIAN OF ROAD


<<< TO HINDUN RIVER/MOHAN NAGAR ROAD

PLUMBING LEGEND:-	
4	110 OD uPVC TERRACE RAIN WATER PIPE
4G	160 OD uPVC TERRACE RAIN WATER PIPE
5	90 OD uPVC BALCONY RAIN WATER PIPE
	EXTERNAL SEWER LINE
	EXTERNAL STORM WATER LINE
MW	DOMESTIC WATER SUPPLY FILLING LINE FROM MUNICIPAL / TANKER LINE.
	IRRIGATION WATER SUPPLY LINE
TW	TUBE WELL WATER SUPPLY LINE
	EXTERNAL FIRE HYDRANT LINE
R.P.	RECHARGE PIT (3000 MM DIA)
D.C.	DESILTING CHAMBER (1000 x 2000 MM DIA)
	VALVE WITH CHAMBER
	NON RETURN VALVE WITH CHAMBER
	FLUSHING WATER SUPPLY
	COLD WATER SUPPLY

PLUMBING LEGEND:-	
	SEWER MANHOLE WITH 560ø MANHOLE COVER.
(I)	910 DIA MANHOLE UPTO 1.67 M DEPTH
(II)	1220 DIA MANHOLE UPTO 2.29 M DEPTH
(III)	1520 DIA MANHOLE ABOVE 2.29 M DEPTH
	STORM WATER MANHOLE WITH 560ø PERFORATED MANHOLE COVER.
(I)	910 DIA MANHOLE UPTO 1.67 M DEPTH
(II)	1220 DIA MANHOLE UPTO 2.29 M DEPTH
(III)	1520 DIA MANHOLE ABOVE 2.29 M DEPTH
	STORM WATER CATCH BASIN SIZE=(600x600)mm
EFH	EXTERNAL FIRE HYDRANT
	2-WAY FIRE BRIGADE WITHDRAWAL CONNECTION.
	3-WAY FIRE BRIGADE INLET CONNECTION.
GH	GARDEN HYDRANT
G.L.	GROUND LEVEL
I.L.	INVERT LEVEL
C.L.	CONNECTION LEVEL

PLUMBING LEGEND:-	
	RAIN WATER HARVESTING
	SPACE FOR SOLAR PANEL

NOTE :- ESS , STP & UGT ARE COMMON FOR OFFICER CITY-1 & M.R HERITAGE



PROJECT :-
REV.SUBMISSION DRAWING FOR THE
PROPOSED GROUP HOUSING
"OFFICER CITY-1", HERITAGE & NITYA HOMES
AT KHASRA NO. 1052 , 1059 & 1060 , 1098
VILLAGE NOORNAGAR GHAZIABAD (U.P.)

PROMOTER :-
MIS. R.K.S.BUILDCON INDIA P.Ltd.
MIS. LOTOUS ENTERPRISES
MIS. PROVIEW INFRASTRUCTURE (P.)Ltd.

DIRECTOR :-
Mr. PUNEET TYAGI

DRAWING TITLE :-
SERVICES PLAN
(sewerage,water supply,drainage,rain
water harvesting)

OWNER'S SIGN ARCHITECT'S SIGN

ANUJ AGARWAL ARCHITECTS
OFFICE - A-244 KAUSHAMBI GHAZIABAD (U.P.)
Ph-0120 - 6454182 / 84, 4165716, TEL. FAX - 2773592
e-mail - arch.anujagarwal@gmail.com

SCALE DEALT BY A. CHAUHAN DATE
DESIGN BY CHECKED BY DRG. No. DG-02