






ROAD



S.NO.	DESCRIPTION
1.	THIS DRAWING REPRESENTS FIRE FIGHTING DETAILS ONLY. FOR ACTUAL CONSTRUCTION/FINISHING, REFER STRUCTURAL/ARCHITECTURAL DETAILS.
2.	PLEASE CO-ORDINATE THIS DRAWING WITH ALL OTHER RELEVANT DRAWINGS OF ALL THE SERVICES.
3.	THE SPINKLER SHALL BE INSTALLED AS PER NBC/ANY OTHERS RELEVANT CODES & STANDARDS AS APPLICABLE.
4.	THE LOCATION OF SPINKLER MAY VARY AS PER FINAL ARCHITECTURAL CO-ORDINATION DRAWING & REFLECTED CEILING PLANS.
5.	SHOP DRAWINGS SHALL BE PREPARED BY THE CONTRACTOR AND SUBMITTED IN CASE OF ANY CHANGES IN LAYOUT AS PER SITE CONDITIONS.

S.NO.	DESCRIPTION	SYMBOL
1.	1500 FIRE HYDRANT PIPE	①
2.	1500 FIRE SPINKLER PIPE	②
3.	800 DRAIN PIPE	③
4.	UP RIGHT SPINKLER	④
5.	PIPE SIZE	Ø DIA
6.	CURTAIN NOZZLE	⑤
7.	DELUGE VALVE	D.V.
8.	FLOW SWITCH	⑥

S.NO.	DESCRIPTION	SYMBOL
1.	FIRE HOSE CABINET FIRE HOSE CABINET COMPRISING OF: a. 1 NO. LANDING VALVE b. 1 NO. HOSE REEL (WITH 30mtr.) c. 2 NOS. 50mtr. LONG ROL HOSE d. 1 NO. BRANCH PIPE e. 1 NO. 9 LITS. WATER CO2 TYPE FIRE EXTINGUISHERS f. 1 NO. 4.5KG CO2 TYPE FIRE EXTINGUISHERS	⑦



REV.	DATE	REMARK
RT	07.04.2017	

PROJECT:-
PLATINUM PREMIER AT
RAMPRASTHA GREENS , GHAZIABAD

CLIENT:-
Ramprastha Realty PVT. LTD.
C-168, Ramprastha Colony, GHAZIABAD

ARCHITECT:-
DESIGNERS' GUILD
UNITED
D-2, SECTOR-7
NOIDA-201301
PH: 0120-4325408
E-MAIL:- DESIGNERSGUILD@GMAIL.COM

PLUMBING & FIRE CONSULTANT :-
PEE CONSULTANTS
815-CDDA FLATS
EAST OF LONI ROAD, DELHI-110093
PH & FAX:- 011-22816297
E-MAIL:- PDSS_IN@YAHOO.COM

SHEET TITLE:-
LOWER BASEMENT FIRE FIGHTING
LAYOUT PLAN - LVL--825

SCALE - N.T.S
DATE-07.04.2017
DRAWN - MANISH
CHECKED - DINESH

DRG. NO
BC/FF/01