

Development Work Plan

1. SEWAGE TREATMENT PLANT (STP):- 350 KLD
2. UNDR GROUND FIRE TANK: - 300 KL
3. UNDER GROUND DOMESTIC TANK: - 110 KL
4. DG PROPOSED:-

For Multiplex - 1 nos 1010 KVA

For Mall & Common Service - 3 nos 1250 KVA & 1 nos 500
KVA (night mode)

TOTAL ELECTRICAL LOAD: - 4070 KVA