

वी गई अनुज्ञा स्वीकृति के दि० 20/11/2020  
से पाँच वर्ष के लिए मान्य होगी।

10 लाख एअ अधिक निर्माण लागत आने पर अधिकतर  
होग अनुमानित निर्माण लागत का (शासनादेश के क्रम में)  
1% तेवर सेस का 10% भाग अग्रिम रूप से जमा करवाया जा  
रहा है। श्वरेश तेवर सेस की धनप्राप्ति से, श्वरेश विभाग में  
पंजीकरण कराते हुए उनके यहाँ जमा करली होगी।

मैंने सलतन मानचित्र का भला-भाँति परीक्षण कर  
लिया है।  
मानचित्र उत्तर प्रदेश नगर योजना एवं विकास  
अधिनियम 1973 को धाराएं 15/निर्माण उपबंधों के  
अनुसार है तथा स्वीकृत योग्य है।  
अवर अभियन्ता  
सहायक अभियन्ता

मानावर सं० 377/2018-21  
यह स्वीकृति उत्तर प्रदेश शासन के दि० 11.11.1973  
(राष्ट्रपति अधिनियम सं० 11/1973) को धारा 15 उपधारा  
3 एवं इस विषय में सम्बन्धित नियमों/उपबंधों के अनुसार की  
गई है। इस स्वीकृति से आने वाले कोई विरोध अधिकार प्राप्त नहीं  
होगा। इस स्वीकृति का कोई प्रभाव सम्पत्ति सम्बन्धी किसी  
अधिकार पर नहीं पड़ेगा और न ही कोई कानूनी रुकावट होगी।

सचिव  
मथुरा-वृन्दावन विकास प्राधिकरण, मथुरा  
दिनांक 20/11/2020



## GENERAL NOTES

| LEGENDS TABLE |                                                                      |        |
|---------------|----------------------------------------------------------------------|--------|
| S.NO          | DESCRIPTION                                                          | SYMBOL |
| 1.            | FRESH WATER SUPPLY DIA TENTATIVELY<br>UPVC 80mm2 PIPE (IS CODE:4985) |        |
| 2.            | NODE SYMBOL                                                          |        |
| 3.            | AIR VALVE                                                            | AV     |
| 4.            | SLUICE VALVE IN CHAMBER                                              | SV     |
| 5.            | SCOUR VALVE                                                          | SC     |
| 6.            | FIRE BRIGADE OUTLET CONNECTION                                       |        |

## NOTES:-

- ALL SIZES OF PIPES INDICATED ARE IN MM.
- ALL POTABLE WATER SUPPLY LINES WILL BE LAID TO AN AVERAGE DEPTH OF ABOUT 1.0 M FINISHED FORMATION LEVEL.
- ALL SLUICE VALVE SHALL BE HOUSED IN BRICK MASONRY CHAMBERS AS / DETAIL.
- ALL VALVES SHALL BE OF CLASS PN-1 CONFORMING TO IS : 780 . & VALVES DIA WILL BE CONSIDER AS PER PIPE DIA.
- FOR DETAILS OF SLUICE VALVE AND FIRE HYDRANT CHAMBER REFER RELEVANT DRAWING. ( CPWD SPECS. )
- FOR LOCATION OF FLUSHING WATER SUPPLY LINES REFER LANDSCAPE PLAN/ROAD SECTION DRAWING.
- PIPE LINES CROSSING UNDER THE ROAD WILL BE ENCASED WITH 150 TH P.C.C. FOR A DISTANCE = ROAD WIDTH +1000 mm ON EITHER SIDE OF ROAD.
- WHEREVER THE WATER LINE IS CROSSING THE SEWER OR STORM WATER THE SAME SHALL BE ENCASED WITH P.C.C.FOR A LENGTH OF 500 mm FROM CENTER OF THE JOINT ON EITHER SIDE.

सीट नं० 7/1 पर चस्पा सभी  
शर्तें मान्य होगी।

CLIENT  
M/S SJP GLOBAL LIMITED

SIGN & SEAL OF AUTHORISED SIGNATORY

MEP CONSULTANT

C TO C Services Consultants Pvt. Ltd.  
F-67, - (Basement) Green Park Main,  
New Delhi-110016 (INDIA)  
Tel. 41618888, 41618866  
E-mail: ctocinfo@ctocconsultants.com



SIGN & SEAL OF ARCHITECT

PROJECT

SHRI RADHA GULMOHAR-3

GOVERDHAN ROAD, MATHURA (U.P.)

MAUZA NAGLA SADOLA:  
KHASRA NO. - 201-206(P), 208-210(P).

MAUZA SATOHA ASGARPUR:  
KHASRA NO. - 26(P), 30-34(P), 57-59(P), 69-71(P), 73(P), 74(1089(P),  
75(P), 77(P), 78(P), 117(P), 118-123, 124-128(P), 130-134(P), 135-138,  
139-141(P), 156(P), 157-159, 160(P), 161, 165.

RWS & LIG PLOT - KHASRA NO. 55(P)

TITLE

WATER SUPPLY LAYOUT PLAN


SHEET No.

SRGU-3-SUB-MEP-03

DATE : 30 Oct 2020

SCALE : NTS

R0



PROVISION FOR WATER SUPPLY LINE CONNECTION  
FROM GUL-3 TO FUTURE EXTENSION

PROVISION FOR WATER SUPPLY LINE CONNECTION  
FROM GUL-3 TO FUTURE EXTENSION

EXISTING  
GULMOHAR-1

FUTURE  
EXTENSION

PROVISION FOR WATER  
SUPPLY LINE CONNECTION

GULMOHAR-3  
EWS & LIG