

Electrical load Calculation - Samridhi Luxuria									
At Plot No- SC-02D, Sector - 150, NOIDA									
S.no	Description	No. of unit	Load per Unit				Total Load		
SUB HEAD - A (Apartment load)									
	Tower - A & L (B+S/G+13)	No. of Tower	=	2	nos.				
1	2B + 2T + STUDY (69 sq M @ 50 W/sqM = 3.47 KW)	52	units	@	3.5	KW	=	180	KW
2	3B + 2T (83 sq M @ 50 W/sqM = 4.14 KW)	28	units	@	4.1	KW	=	116	KW
3	3B + 3T (96 sq M @ 50 W/sqM = 4.78 KW)	28	units	@	4.8	KW	=	134	KW
	Tower - B & K (B+S/G+15)	No. of Tower	=	2	nos.				
4	2B + 2T + STUDY (69 sq M @ 50 W/sqM = 3.47 KW)	30	units	@	3.5	KW	=	104	KW
5	3B + 2T (83 sq M @ 50 W/sqM = 4.14 KW)	62	units	@	4.1	KW	=	257	KW
6	3B + 3T (95 sq M @ 50 W/sqM = 4.77 KW)	32	units	@	4.8	KW	=	153	KW
	Tower - C & J (B+S/G+17)	No. of Tower	=	2	nos.				
7	2B + 2T + STUDY (69 sq M @ 50 W/sqM = 3.47 KW)	70	units	@	3.5	KW	=	243	KW
8	3B + 2T (83 sq M @ 50 W/sqM = 4.14 KW)	34	units	@	4.1	KW	=	141	KW
9	3B + 3T (95 sq M @ 50 W/sqM = 4.77 KW)	36	units	@	4.8	KW	=	172	KW
	Tower - D & I (B+S/G+19)	No. of Tower	=	2	nos.				
10	2B + 2T + STUDY (69 sq M @ 50 W/sqM = 3.47 KW)	78	units	@	3.5	KW	=	270	KW
11	3B + 2T (83 sq M @ 50 W/sqM = 4.14 KW)	38	units	@	4.1	KW	=	157	KW
12	3B + 3T (95 sq M @ 50 W/sqM = 4.77 KW)	40	units	@	4.8	KW	=	191	KW
	Tower - E & H (B+S/G+21)	No. of Tower	=	2	nos.				
13	2B + 2T + STUDY (69 sq M @ 50 W/sqM = 3.47 KW)	42	units	@	3.5	KW	=	146	KW

Electrical load Calculation - Samridhi Luxuria										
At Plot No- SC-02D, Sector - 150, NOIDA										
S.no	Description		No. of unit		Load per Unit			Total Load		
14	3B + 2T		86	units	@	4.1	KW	=	356	KW
	(83 sq M @ 50 W/sqM = 4.14 KW)									
15	3B + 3T		44	units	@	4.8	KW	=	210	KW
	(95 sq M @ 50 W/sqM = 4.77 KW)									
Tower - F & G (B+S/G+23)			No. of Tower		=	2	nos.			
16	2B + 2T + STUDY		92	units	@	3.5	KW	=	319	KW
	(69 sq M @ 50 W/sqM = 3.47 KW)									
17	3B + 2T		48	units	@	4.1	KW	=	199	KW
	(83 sq M @ 50 W/sqM = 4.14 KW)									
18	3B + 3T		46	units	@	4.8	KW	=	219	KW
	(95 sq M @ 50 W/sqM = 4.77 KW)									
								Total Load =	3566	KW
By taking Overall Diversity factor							50 %	=>	1783	KW
By taking Power factor							0.90	=>	1980	KVA
Electrical Load A = 1980 KVA										
SUB HEAD - B (COMMON LOAD)										
<u>COMMON SERVICES - TOWERS</u>										
Tower - A & L (B+S/G+13)			No. of Tower		=	2	nos.			
19	Elevators (13 Passenger) 1.0 mps		4	nos	@	7	KW	=	28	KW
20	Common Lights		2	towers	@	3	KW	=	6	KW
Tower - B & K (B+S/G+15)			No. of Tower		=	2	nos.			
21	Elevators (13 Passenger) 1.5 mps		4	nos	@	12	KW	=	48	KW
22	Common Lights		2	towers	@	3	KW	=	6	KW
Tower - C & J (B+S/G+17)			No. of Tower		=	2	nos.			
23	Elevators (13 Passenger) 1.5 mps		4	nos	@	12	KW	=	48	KW
24	Common Lights		2	towers	@	3	KW	=	6	KW
Tower - D & I (B+S/G+19)			No. of Tower		=	2	nos.			
25	Elevators (13 Passenger) 1.5 mps		4	nos	@	12	KW	=	48	KW
26	Common Lights		2	towers	@	3	KW	=	6	KW

Electrical load Calculation - Samridhi Luxuria										
At Plot No- SC-02D, Sector - 150, NOIDA										
S.no	Description	No. of unit		Load per Unit			Total Load			
	Tower - E & H (B+S/G+21)	No. of Tower	=	2	nos.					
27	Elevators (13 Passenger) 1.75 mps	4	nos	@	12	KW	=	48	KW	
28	Common Lights	2	towers	@	3	KW	=	6	KW	
	Tower - F & G (B+S/G+23)	No. of Tower	=	2	nos.					
29	Elevators (13 Passenger) 1.75 mps	4	nos	@	12	KW	=	48	KW	
30	Common Lights	2	towers	@	3	KW	=	6	KW	
COMMON SERVICES - General										
31	Community / Club / Swimming Pool						=	100	KW	
32	Tube wells / Water Supply Pumps	1	Job	@	45	KW	=	45	KW	
33	Sewage Treatment Plant	1	Job	@	45	KW	=	45	KW	
34	External / Gate / Landscape lighting	1	set	@	10	KW	=	10	KW	
35	Basement lights	70896	sqm	@	0.7	W/sqm	=	50	KW	
36	Basement Ventilation						=	200	KW	
37	Commercial						=	90	KW	
38	Fire pumps (only jockey pumps have been considered)	2	set	@	15	KW	=	30	KW	
							Total Load =	874	KW	
					By taking Overall Diversity factor	100 %	=>	874	KW	
					By taking Power factor	0.90	=>	970	KVA	
Electrical Load B = 970 KVA										
Total Residential Electrical Load A + B								=>	2950	KVA
Total Electrical Load = 2950 KVA										
Recommended Transformer (at 85% loading) = 2 nos 2000 KVA.										

Essential Electrical load Calculation - Samridhi Luxuria									
At Plot No- SC-02D, Sector - 150, NOIDA									
S.no	Description	No. of unit		Load per Unit			Total Load		
SUB HEAD - A (Apartment load)									
	Tower - A & L (B+S/G+13)	No. of Tower		=	2	nos.			
1	2B + 2T + STUDY	52	units	@	1.0	KVA	=	52	KVA
2	3B + 2T	28	units	@	3.0	KVA	=	84	KVA
3	3B + 3T	28	units	@	3.0	KVA	=	84	KVA
	Tower - B & K (B+S/G+15)	No. of Tower		=	2	nos.			
4	2B + 2T + STUDY	30	units	@	1.0	KVA	=	30	KVA
5	3B + 2T	62	units	@	3.0	KVA	=	186	KVA
6	3B + 3T	32	units	@	3.0	KVA	=	96	KVA
	Tower - C & J (B+S/G+17)	No. of Tower		=	2	nos.			
7	2B + 2T + STUDY	70	units	@	1.0	KVA	=	70	KVA
8	3B + 2T	34	units	@	3.0	KVA	=	102	KVA
9	3B + 3T	36	units	@	3.0	KVA	=	108	KVA
	Tower - D & I (B+S/G+19)	No. of Tower		=	2	nos.			
10	2B + 2T + STUDY	78	units	@	1.0	KVA	=	78	KVA
11	3B + 2T	38	units	@	3.0	KVA	=	114	KVA
12	3B + 3T	40	units	@	3.0	KVA	=	120	KVA
	Tower - E & H (B+S/G+21)	No. of Tower		=	2	nos.			
13	2B + 2T + STUDY	42	units	@	1.0	KVA	=	42	KVA
14	3B + 2T	86	units	@	3.0	KVA	=	258	KVA
15	3B + 3T	44	units	@	3.0	KVA	=	132	KVA
	Tower - F & G (B+S/G+23)	No. of Tower		=	2	nos.			
16	2B + 2T + STUDY	92	units	@	1.0	KVA	=	92	KVA
17	3B + 2T	48	units	@	3.0	KVA	=	144	KVA
18	3B + 3T	46	units	@	3.0	KVA	=	138	KVA
							Total Load =	1930	KVA
By taking Overall Diversity factor						80 %	=>	1544	KVA
Electrical Load A = 1544 KVA									

Essential Electrical load Calculation - Samridhi Luxuria									
At Plot No- SC-02D, Sector - 150, NOIDA									
S.no	Description	No. of unit		Load per Unit		Total Load			
SUB HEAD - B (COMMON LOAD)									
<u>COMMON SERVICES - TOWERS</u>									
Tower - A & L (B+S/G+13)		No. of Tower		=	2	nos.			
19	Elevators (13 Passenger) 1.0 mps	4	nos	@	7	KW	=	28	KW
20	Common Lights	2	towers	@	3	KW	=	6	KW
Tower - B & K (B+S/G+15)		No. of Tower		=	2	nos.			
21	Elevators (13 Passenger) 1.5 mps	4	nos	@	12	KW	=	48	KW
22	Common Lights	2	towers	@	3	KW	=	6	KW
Tower - C & J (B+S/G+17)		No. of Tower		=	2	nos.			
23	Elevators (13 Passenger) 1.5 mps	4	nos	@	12	KW	=	48	KW
24	Common Lights	2	towers	@	3	KW	=	6	KW
Tower - D & I (B+S/G+19)		No. of Tower		=	2	nos.			
25	Elevators (13 Passenger) 1.5 mps	4	nos	@	12	KW	=	48	KW
26	Common Lights	2	towers	@	3	KW	=	6	KW
Tower - E & H (B+S/G+21)		No. of Tower		=	2	nos.			
27	Elevators (13 Passenger) 1.75 mps	4	nos	@	12	KW	=	48	KW
28	Common Lights	2	towers	@	3	KW	=	6	KW
Tower - F & G (B+S/G+23)		No. of Tower		=	2	nos.			
29	Elevators (13 Passenger) 1.75 mps	4	nos	@	12	KW	=	48	KW
30	Common Lights	2	towers	@	3	KW	=	6	KW
<u>COMMON SERVICES - General</u>									
31	Community / Club / Swimming Pool						=	100	KW
32	Tube wells / Water Supply Pumps	1	Job	@	45	KW	=	45	KW
33	Sewage Treatment Plant	1	Job	@	45	KW	=	45	KW
34	External / Gate / Landscape lighting	1	set	@	10	KW	=	10	KW
35	Basement lights	70896	sqm	@	0.7	W/sqm	=	50	KW
36	Basement Ventilation						=	200	KW
37	Commercial						=	90	KW

Essential Electrical load Calculation - Samridhi Luxuria										
At Plot No- SC-02D, Sector - 150, NOIDA										
S.no	Description	No. of unit			Load per Unit			Total Load		
38	Fire pumps (only jockey pumps have been considered)	2	set	@	15	KW	=	30	KW	
							Total Load	=	874	KW
By taking Overall Diversity factor						50	%	=>	437	KW
By taking Power factor						0.80		=>	550	KVA
Electrical Load B = 550 KVA										
Total Residential Electrical Load A + B								=>	2094	KVA
Total Electrical Load = 2094 KVA										
Recommended DG sets (at 85% loading) = 1 nos 1250 KVA & 2 nos 600 KVA.										