

Regd Post

Tele: 23010231/5216

Directorate of Ops (ATS)
Air Headquarters
Vayu Bhawan
Rafi Marg
New Delhi -110106

Air HQ/S 17726/4/ATS (Ty BM-MCCCXLVI)

19. Apr 16

M/s AMV Infratech Pvt Ltd Resiedent-12A
Charu Chandra Puri, Colony Doudpur,
Gorakhpur-273001

NOC FROM AVIATION ANGLE FOR
CONSTRUCTION OF BUILDING

Dear Sir,

1. Please refer your application dated 14 Sep 15 on the subject.
2. The application has been examined under Gazette of India GSR 751 (E), Works of Defence Act 1903 and other relevant orders on the subject. Air HQ has no objection for construction of **28.67 M** high multistoried residential building at Arazi No. 68, 69 Mohalla Khorbar urf Suba bazar, Gorakhpur (UP), subject to the following conditions:
 - (a) The NOC is from 'Aviation angle' with respect to Air Force Station Gorakhpur and cannot be used as document for any other purpose/ claim whatsoever, including ownership of land.
 - (b) The applicant is responsible to obtain NOC/ all statutory clearances from the concerned authorities including approval of building plans. Clearance shall also be obtained separately from any other defence establishment in the vicinity of proposed construction.
 - (c) The site elevation and site coordinates provided by the applicant are taken for calculation of the permissible top elevation of the proposed structure. If, however, at any stage it is established that the actual site elevation and site coordinates are different from those provided by the applicant, the NOC will be invalid.
 - (d) The issue of the NOC is further subject to the provisions of Sec 9 A of the Indian Aircraft Act, 1934 and those of any notifications issued there under from time to time including the Aircraft (Demolition of Obstruction caused by buildings and trees etc) Rules, 1994.
 - (e) The vertical extent (highest point) of the buildings at Latitude - 26° 43' 09" N Longitude 83° 25' 51" E shall not exceed **107.67 metres** above mean sea level or **28.67 meters** above ground level **whichever is lower**. No extension or structure permanent or temporary (eg. Cranes, Antennas, mumtee, Lighting Arresters, lift machine room, overhead water tank, cooling towers, sign boards, any attachment of fixtures of any kind) shall be permitted above the cleared height.

(f) Standard obstruction lightings as per IS 5613 notification and International Civil Aviation Organization (ICAO) standards as stipulated in ICAO-Annex-14 is to be provided by the company. The lights shall be kept 'ON' at all times. Provision shall be made for standby power supply to keep the lights 'ON' during power failure. Company shall carry out periodic maintenance of the lights to keep them in serviceable and visible condition.

(g) A garbage treatment plant shall be installed prior to the construction of buildings for the purpose of avoiding bird activity. The plant shall be shown to the AOC or his nominated representative at Air Force Station Gorakhpur on installation.

(h) No light or a combination of lights which by reason of its intensity, configuration or colour may cause confusion with the aeronautical ground lights of the Airport shall be installed at the site at any time during or after the construction of the building.

(j) The commencement and completion of construction including installation of obstruction lights shall be intimated to AOC, AF Station Gorakhpur and CATCO, HQ CAC, IAF, Bhamrauli, Allahabad, UP. Failure to render these certificates within the stipulated time shall lead to cancellation of NOC.

(k) The NOC is valid for five years from the date of its issue. If the building/ structure/ chimney is not constructed and completed within this period, the applicant shall be required to obtain a fresh NOC from Indian Air Force. Request for revalidation of NOC will not be entertained after the expiry of validity period.

(l) The applicant shall obtain necessary security clearance from MHA/IB prior to employing any foreign National at the site.

Yours faithfully,



(BJ Mammen)
Group Captain
Director Operations (ATS)