

Electrical Load Calculation - Migsun Atharva Ghaziabad UP (Plot - A)

S.no	Description		No. of unit		Load per Unit		Total Load	
	<u>Sub Head - (A)</u>							
1	Tower - A		296	units	@ 5.00	KW	=	1480 KW
2	Tower - B		124	units	@ 6.00	KW	=	744 KW
3	Tower - C		266	units	@ 5.00	KW	=	1330 KW
4	Tower - D		86	units	@ 10.00	KW	=	860 KW
5	Service Apartments		77	units	@ 3.00	KW	=	231 KW
						Total Load (A)	=	4645 KW
						By taking Overall Diversity factor	50 % =>	2323 KW
	<u>Sub Head - (B)</u>							
6	Commerical (Shoping & Multilpex)	20299	sqm	@ 120	W/sqm		=	2436 KW
						Total Load (B)	=	2436 KW
						By taking Overall Diversity factor	75 % =>	1827 KW
						Total Load (A+B)	=	4149 KW
						By taking Power factor	0.90 =>	4610 KVA

Electrical Load = 4610 KVA

Recommended Transformer for Residential units & Commercial = 15 Nos. 400 KVA.

	<u>Sub Head - (C)</u>							
	Common Services (Towers)			Nos of Tower		=	5	
7	Elevators		26	nos	@ 12	KW	=	312 KW
8	Escalator		14	nos	@ 10	KW	=	140 KW
9	Common Lights		5	towers	@ 5	KW	=	25 KW
	<u>Common Services - General</u>							
10	Community Hall						=	75 KW
11	Tube wells/Water Supply Pumps	1	Job	@ 55	KW	=	55 KW	
12	STP		1	Job	@ 55	KW	=	55 KW
13	External / Gate / Landscape lighting	1	Set	@ 8	KW	=	8 KW	
14	Basement lighting	55767	sqm	@ 0.7	W/sqm	=	39 KW	
15	Basement Ventillation						=	100 KW
16	Fire pumps (only jockey pumps have been considered)	2	set	@ 10	KW	=	20 KW	
						Total Load (C)	=	829 KW
						By taking Overall Diversity factor	70 % =>	580 KW
						By taking Power factor	0.90 =>	640 KVA
Electrical Load = 640 KVA								
Recommended Transformer for Common Servies = 2 Nos. 400 KVA.								

Essential Electrical Load Calculation - Migsun Atharva Ghaziabad UP (Plot - A)								
S.no	Description	No. of unit		Load per Unit			Total Load	
	<u>Sub Head - (A)</u>							
1	Tower - A	296	units	@ 1.00	KVA	=	296	KVA
2	Tower - B	124	units	@ 1.00	KVA	=	124	KVA
3	Tower - C	266	units	@ 1.00	KVA	=	266	KVA
4	Tower - D	86	units	@ 1.00	KVA	=	86	KVA
5	Service Apartments	77	units	@ 1.00	KVA	=	77	KVA
					Total Load (A) =		849	KVA
By taking Overall Diversity factor						90 % =>	764	KVA
Electrical Load - (A) = 764 KVA								
	<u>Sub Head - (B)</u>							
6	Commerical (Shoping & Multilplex)	20299	sqm	@ 120.0	W/sqm	=	2436	KW
					Total Load (B) =		2436	KW
By taking Overall Diversity factor						75 % =>	1827	KW
By taking Power factor						0.80 =>	2284	KVA
Electrical Load - (B) = 2284 KVA								
	<u>Sub Head - (C)</u>							
Common Services (Towers)			Nos of Tower		=	5		
7	Elevators		26	nos	@ 12	KW	=	312 KW
8	Escalator		14	towers	@ 10	KW	=	140 KW
9	Common Lights		5	towers	@ 5	KW	=	25 KW
<u>COMMON SERVICES - General</u>								
10	Community Hall						=	75 KW
11	Tube wells/Water Supply Pumps	1	Job	@ 55	KW	=	55 KW	
12	STP		1	Job	@ 55	KW	=	55 KW
13	External / Gate / Landscape lighting	1	Set	@ 8	KW	=	8 KW	
14	Basement lighting	55767	sqm	@ 0.7	W/sqm	=	39 KW	
15	Basement Ventillation						=	100 KW
16	Fire pumps (only jockey pumps have been considered)	2	set	@ 10	KW	=	20 KW	
					Total Load (C) =		829	KW
By taking Overall Diversity factor						70 % =>	580	KW
By taking Power factor						0.80 =>	730	KVA
Electrical Load - (C) = 730 KVA								
Total Electrical Load (A) + (B) + (C)							=>	3778 KVA
Total Essential Electrical Load = 3778 KVA								
Recommended DG Sets = 3 no. 1250 KVA & 1 no. 750 KVA.								