

दी गई अनुज्ञा स्वीकृति के दि० 20/11/2020 से पांच वर्ष के लिए मान्य होगी।

10 लाख एवं अधिक निर्माण लागत आने पर प्राधिकरण द्वारा अनुमानित निर्माण लागत का (सामान्यतः के कम से 1% लेबर सेस का 10% भाग अधिम रूप से जमा करवाया जा रहा है। विशेष लेबर सेस की धनराशि सीधे भ्रम विभाग में पंजीकरण करते हुए उनके दल्ले जमा करनी होगी।

मैंने सलग्न मानचित्र का भली-भाँति परीक्षण कर लिया है। मानचित्र उत्तर प्रदेश नगर योजना एवं विकास अधिनियम 1973 की धाराएं 15/निर्माण उपबंधों के अनुसार है तथा स्वीकृत योग्य है।

अवर अभियन्ता

सहायक अभियन्ता

मानचित्र संख्या... 377... 1/1... 12/10/2020...
यह स्वीकृति उत्तर प्रदेश योजना और विकास अधिनियम 1973 (संशुद्धित अधिनियम संख्या-11-1973) की धारा 15 उपधारा 3 एवं इस विषय में सम्बन्धित नियमों/उपबंधों के अनुसार की गई है। इस स्वीकृति से आगामी कोई भी प्राव्य सम्पत्ति सम्बन्धी किसी अधिकार पर नहीं प्रभाव डालेगा और न ही कोई कानूनी रुकावट होगी।



GENERAL NOTES

LEGEND TABLE

S.NO.	SYMBOL	DESCRIPTION
1.		CIRCULAR MANHOLE (Ø AS/ØDEPTH)
2.		SEWAGE SN-4 PIPE (PIPE Ø AS PER DESIGN CALCULATION)
3.		RECTANGULAR MANHOLE SIZE 450x600mm FOR BRANCH LINE
4.		RECTANGULAR MANHOLE (600x600mm) FOR PLOT (OWNER SCOPE)
5.	F.F.L.	FINISHED FORMATION LEVEL IN M.
6.	I.L.	INVERT LEVEL OF MANHOLE IN M.
7.	C.L.	CONNECTION LEVEL

NOTES:-

- FOR SEWAGE PIPES DIA 200 TO 400mm STRUCTURED WALL PLASTIC PIPES CLASS SN-4 AS/IS-18086 OF ALONG THE ROAD IN GREEN STRIP & SN4 UNDER THE ROADS WITH SLOPES AS
- FOR 150mm SLOPE=1:200
- FOR 200mm SLOPE=1:300
- FOR 300mm SLOPE=1:400
- FOR 400mm SLOPE=1:500
- MANHOLE (FOR SEWAGE SYSTEM)
(MANHOLES WITH SFRP PERFORATED COVERS ON MAIN LINE)
- SIZE = (800mm FOR DEPTH 1000mm TO 1500mm)
- SIZE = (1200mm FOR DEPTH 1600mm TO 3000mm)
- SIZE = (800x800mm FOR DEPTH 1000mm TO 1500mm)
- MANHOLE COVER
- FOR CIRCULAR MANHOLES ON MAIN LINE
- FOR MANHOLES, SFRP COVER & FRAME (HEAVY DUTY) HD-20 GRADE DESIGNATION) 500mm INTERNAL DIMENSION CONFIRMING TO IS-12862 TOTAL WEIGHT OF COVER & FRAME TO BE NOT LESS THAN 100 kg.)
- FOR RECTANGULAR MANHOLE
- COVERED WITH 600x600mm PRECAST R.C.C. HORIZONTAL ORATING WITH FRAME OR SFRP COVERS AND FRAME COMPLETE AS PER STANDARD DESIGN
- FOR CATCH BASIN & MANHOLES DETAILS REFER DETAIL DRAWING NO.
- CATCH BASIN & MANHOLES TOPS/PERFORATED COVERS SHALL BE FINISHED WITH F.F.L. AS/LANDSCAPE DRAWING
- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH OTHER DRAWINGS I.E. ARCHITECTURE, STRUCTURAL ELECTRICAL & LANDSCAPE DRAWINGS.
- CC 1:5-10 UP TO HAUNCHES SHALL BE PROVIDED UNDER ALL PIPES ON MAIN LINE AND C.C. SHALL BE PROVIDED AROUND PIPES UNDER ROADS.
- ALL SEWAGE LINES ARE OF 200mm DIA STRUCTURED WALL PLASTIC PIPES CLASS SN-4 UNTIL UNLESS MENTIONED.
- ALL LINES ARE OF 200mm DIA SN-4 WITH AL ROUND ENCASED FROM RECTANGULAR CATCH BASIN TO CIRCULAR MANHOLE
- ALL MANHOLES AND CATCH BASINS SHALL BE STRATEGICALLY LOCATED WITHOUT DISTURBING THE MAIN SCHEME
- LENGTH OF LINE MENTIONED THIS IS FROM CENTER TO CENTER OF MANHOLE / CHAMBER
- BEFORE TAKING UP THE EXECUTION, THE FEASIBILITY OF CONNECTION OF SW DRAINS WITH THE OUTSIDE DRAINS MAY PLEASE BE CHECKED ANY DISCREPANCY MAY BE REPORTED TO THE CONSULTANT
- FOR INTERMEDIATE MANHOLE LEVELS SHALL BE INTERPOLATED
- ROAD CROSSING SHALL BE AS PER DESIGN

CLIENT
M/S SJP GLOBAL LIMITED

SIGN & SEAL OF AUTHORISED SIGNATORY

MEP CONSULTANT

C TO C Services Consultants Pvt. Ltd.
F-67, - (Basement) Green Park Main,
New Delhi-110016 (INDIA)
Tel.: 41618888, 41618866
E-mail: ctocinfo@ctocconsultants.com



SIGN & SEAL OF ARCHITECT

PROJECT

SHRI RADHA GULMOHAR-3
GOVERDHAN ROAD, MATHURA (U.P.)

MAUZA NAGLA SADOLA:-
KHASRA NO.- 201-206(P), 208-210(P).

MAUZA SATOHA ASGARPUR:-
KHASRA NO.- 26(P), 30-34(P), 57-59(P), 69-71(P), 73(P), 74(108(P),
75(P), 77(P), 78(P), 117(P), 118-123, 124-126(P), 130-134(P), 135-136,
139-141(P), 156(P), 157-159, 160(P), 161, 165.

EWIS & LIG PLOT - KHASRA NO. 85(P)

TITLE

SEWER LAYOUT PLAN

SHEET No.

SRGU-3-SUB-MEP-04

DATE : 30 Oct 2020

SCALE : NTS

R0



PROVISION FOR SEWERAGE LINE CONNECTION FROM GUL-3 TO FUTURE EXTENSION

EXISTING GULMOHAR-1

FUTURE EXTENSION

SEWER OUTFLOW TO MAIN ROAD

GULMOHAR-3
EWS & LIG