



LEGEND OF FIRE PUMP			
SYM.	DESCRIPTION	NOS OF PUMP	CAPACITY
F1	DIESEL DRIVEN FIRE PUMP	1NO	2200LPM
F2	ELECTRICAL DRIVEN FIRE HYDRANT PUMP	1NO	2200LPM
F3	ELECTRICAL DRIVEN JOCKEY PUMP	1NO	180 LPM
F4	ELECTRICAL DRIVEN SPRINKLER PUMP	1NO	2200LPM
F5	WATER CURTAIN PUMP	1NO	1800LPM

LEGEND OF PLUMBING PUMP		
SYM.	DESCRIPTION	NOS OF PUMP
P1	RAW WATER TRANSFER PUMPS	2(TW+1S)
P2	DOMESTIC WATER TRANSFER PUMPS FOR OHT	2(TW+1S)
A27	ACTIVATED CARBON FILTER	NOS.
M2F	QUICK MEDIA FILTER	NOS.
RF	SOFTNER	NOS.
RT	BRINE TANK	NOS.

FIRE LEGEND:		
SYM.	DESCRIPTION	IN CLING
1	MULTI FUNCTION DETECTOR	IN CLING
2	ROCKED CIRCULATING FLAMES	IN CLING
3	MANUAL CALL POINT	IN CLING
4	FAULT INDICATOR AT	IN CLING
5	MONITOR MODULE	IN CLING
6	FIRE ALARM BELL	IN CLING

NOTES:

THIS ENTIRE DEVELOPEMENT HAS BEEN CONCEIVED  
DESIGNED AND DRAFTED ON THE BASIS OF THE FOLLOWING  
PARAMETRES.

1. ALL DIMENSIONS. ARE IN MM.
2. DIMENSIONS NOT TO BE SCALED

DRAWING TITLE:

FIRE ALARM LAYOUT - BASEMENT

PROJECT TITLE:

ANTHELA- AFFORDABLE HOUSING AT  
SECTOR 12D,AWAS VIKAS SIKANDRA  
YOJNA, AGRA

CLIENT:

M/S OP CHAINS HOUSINGS  
LLP & M/S BHARAT NAGAR HOUSING

DRAWN BY:

NIKITA

CHECKED BY:

DD UPADHYAY

SHEET NO :-

SCALE 1:300

NORTH:



CLIENT

ARCHITECT

*Peetush Khatwani*  
PEETUSH KHATWANI  
ARCHITECT  
CA/0912004

ARCHITECT:

NEXUSPLUS  
CONSULTANTS PVT. LTD.  
B-116 2ND FLOOR, SECTOR-50,  
NOIDA-201301  
PHONE NO. 0120 4355781 / 4250663

**nexus**  
architects

BASEMENT PLAN