



NOTES : WATER SUPPLY

1. The depth of domestic water supply main shall be - 1000 mm
2. The depth of rising main shall be - 1000 mm
3. The depth of municipal line shall be - 1000 mm
4. The depth of Recycle (Flushing / Irrigation line shall be) - 1100 mm
5. Pipe material for external Domestic water supply, tube well rising main, municipal line shall be : HDPE (PE100) PN8 with Butt Welded Joints / GI & DI

LEGEND :

S. No.	SYMBOL	DESCRIPTION
1.		DOMESTIC WATER SUPPLY LINE
2.		IRRIGATION WATER LINE
3.		RISING MAINS FROM TUBE WELL
4.		MUNICIPAL WATER LINE
5.		ISOLATING VALVE
6.		YARD HYDRANT
7.		GARDEN HYDRANT
8.		

R0	11.04.2024	ISSUED AS GFC
Rev. No.	Date	Revision

Project
Para Group Housing
At Kabir Nagar, Lucknow

Title
External Coordination Plan

Subtitle
External Water Supply Drawing

Drawing released for
☐ APPROVAL ☐ SUBMISSION
☐ ADVANCE COPY ☒ CONSTRUCTION

Drg. No. **PARA / EXT / PL - 03** Drawn by **Mahesh**

Scale **1:1.6** Designed by **Devesh Agarwal**

Date **June 2024** Checked by **Devesh Agarwal**

Architect
VISHAL & ASSOCIATES
Office : 707 - 7th Floor, Urbnac Building, Gomti Nagar, Lucknow - 226010
Email : vishal.in.lucknow@gmail.com

Services Consultant
VISION TO SERVICES CONSULTANTS
 Office : 3 Vijayeeepur, Behind Amar Shaheed Path
Vibhuti Khand, Gomti Nagar, Lucknow - 226010
Email : vision2services@gmail.com
Tel No : +91-7355437439