

Project Specification


Sewer System	Sewer line of 250 mm dia of RCC hume pipe would be laild as per approved design/drawing, Manholes/Chamber would be built as per approved design/drawing. Sewer connecting chamber would be provided in each plot for sewer disposal.
Water Supply	Water supply lines of 100mm, 125mm & 150 mm dia, sluice valve, air relief valve and fire hydrant valve would be provided as per approved design/drawing Water connection would be provided is each plot for water supply.
Road Work	12 mtr wide bituminous roads having crust thickness of 0.475mtr. and Carriage way width of 4.50 mtr. Other specification as per UPAVP/UPPWD/MORTH.
Drain	Brick work type drain would be built on both side of road for disposal of rain/storm water as per approved design/drawing.

Note:- All work would be done by UPPWD & UPAVP specification.


J.E.




A.E.


J.E.